



Comment Resolution Letter

Dear Mr. Nye and Mastin,

Below are brief responses to the comments received from Boulder County on September 8, 2015 for building permits BP-15-0676, BP-15-1793, and BP-15-1654:

Comment 1: Drawing No. 510-23-01-0001 "LIME INJECTION & ACTIVATED CARBON SYSTEMS PLAN VIEW POWER AND CONTROL DISTRIBUTION": This drawing shows the proposed routing of the conduit and feeder from the Substation in the Homogenizing Equipment Room to the new MCC in the blower building. 2(3-350MCM+#2G)3"C will serve the new MCC.

Comment 2 and 3: Drawing No E-2 "MCC_LI_CA ELECTRICAL LOAD SUMMARY AND FAULT CURRENT": This drawing is a load summary for the new MCC in the blower building, and incorporates all loads to be fed from the new MCC. All loads are calculated as concurrent. The new MCC is fed with 600 amps at 480V, 3-phase, and has a total demand load of 313 Amps currently proposed. A fault current analysis is also included on this drawing to show the available fault current at the new MCC, and sub-panels fed from the MCC. CEMEX provided a fault current analysis performed by Eaton-Cutler Hammer from December of 2014, which gave the available fault current at the Substation in the Homogenizing Equipment Room, which will serve the new MCC. This value of 20, 610 amps was used to then compute the available fault current at the new MCC. The new MCC has a bus rating of 65,000 AIC, with an actual available fault current at the MCC of 13,914 AIC.

Comment 4: Drawing 00-2G "SITE PLAN HAZARDOUS SITE LOCATIONS". This drawing shows the locations on the site that could be considered hazardous. These locations are annotated and approximate boundaries are hatched. The drawing also show the location of the proposed Lime Injection Silo, Blower Building, and Activated Carbon Silo.