custom REQ_Selected_Requirements

01_Requirements

«requirement»
OR041 Low supply alarm and pump switching

tags
id = OR041
text = <memo>

«requirement»
OR041.1 Low pressure alarm for seawater cooling

tags
id = OR041.1
text = <memo>

«requirement»
OR041.2 Standby pump activation for low supply

tags
id = OR041.2
text = <memo>

«requirement»
OR008 Temperature control valve setting and lo

tags
id = OR008
text = <memo>

[Source requirement] The setpoint and installation position of the temperature control valve must be verified against the main engine requirements; otherwise, the water temperature may not be controlled within the appropriate range.

«requirement»
OR008.1 Valve setting verification for temperatu

tags
id = OR008.1
text = <memo>

The setpoint of the temperature control valve shall be verified against the main engine requirements to ensure the water temperature is controlled within the appropriate range.
Criterion: Engine outlet water temperature controlled between 90 and 100 °C
Grade: B
Verification: Test
Cited: E-SYS-COMP-006

«requirement»
OR008.2 Valve location for responsive temperatur

tags
id = OR008.2
text = <memo>

The installation position of the temperature control valve shall meet the distance requirement between the sensor and the valve to ensure timely water temperature control response.
Criterion: Distance between the temperature sensor and the three-way mixing valve shall be 10 to 15 times the pipe diameter
Grade: C
Verification: Inspection
Cited: E-TCV-TEMP-100

«requirement»
OR008.3 Temperature control valve pressure drop

tags
id = OR008.3
text = <memo>

The pressure drop across the temperature control valve shall meet the design requirements to ensure normal system operation.
Criterion: Pressure drop across the three-way valve is 0.3 to 0.6 bar
Grade: B
Verification: Test
Cited: E-TCV-TEMP-099

«requirement»
OR052 Maintenance space without pipe removal

tags
id = OR052
text = <memo>

«requirement»
OR052.1 Adequate maintenance space for pump part

tags
id = OR052.1
text = <memo>

«requirement»
OR052.2 Adequate maintenance space for pump part

tags
id = OR052.2
text = <memo>

«requirement»
OR052.3 Adequate maintenance space for pump part

tags
id = OR052.3
text = <memo>