








NOTES:-


- सभी माप मिलीमीटर में तथा ऊंचाई मीटर में दिए गए हैं।
- ALL DIMENSIONS ARE IN MILLIMETERS AND LEVELS IN METERS.
- THE DEFINITION OF 'A', 'B' LINE AND VARIOUS CLASSES OF EXCAVATION SHOWN SHALL BE AS PER SECTION B.3 OF TECHNICAL SPECIFICATIONS.
- UNDERGROUND EXCAVATION INCLUDING PROTECTION OF TUNNEL INVERT SHALL BE CONFORMING TO SECTION B.3 OF TECHNICAL SPECIFICATIONS.
- ROCK BOLTS/ANCHORS SHOWN IN THE DRAWING SHALL BE CONFORMING TO SECTION B.4 OF TECHNICAL SPECIFICATIONS.
- MINOR MODIFICATION IN THE LENGTH, ORIENTATION, PATTERN AND LOCATION OF ROCK BOLTS/ANCHORS MAY BE DONE TO SUIT THE SITE CONDITIONS WITH THE APPROVAL OF ENGINEER-IN-CHARGE.
- SFR SHOTCRETE SHOWN IN THE DRAWING SHALL BE APPLIED AS SPECIFIED IN SECTION B.5 OF TECHNICAL SPECIFICATIONS. IF REQUIRED, PLAIN SHOTCRETE WITH WIREMESH CAN BE USED WITH THE APPROVAL OF ENGINEER-IN-CHARGE. 50MM THK. MINIMUM SHOTCRETE SHALL BE PROVIDED AS FINAL SUPPORT IN ENTIRE LENGTH OF TUNNEL IRRESPECTIVE OF ROCK CLASS.
- 45ø 5000 LONG (INTO ROCK) CONSOLIDATION GROUTING @3000 C/C STAGGERED BOTHWAYS SHALL BE PROVIDED IN CLASS VA OR AS DIRECTED BY ENGINEER-IN-CHARGE, AS PER SECTION B.7 OF TECHNICAL SPECIFICATION.
- PREGROUTING/FOREPOLING MAY BE USED WHERE RMR VALUE IS LESS THAN 35 OR AS DIRECTED BY ENGINEER-IN-CHARGE.
- M25/A40 GRADE FOR INVERT & OVERT CONCRETE AND M15/A40 FOR BACKFILL CONCRETE CONFORMING TO SECTION B.9 OF TECHNICAL SPECIFICATIONS SHALL BE USED.
- FOR CONCRETE DETAILS AND DRAINAGE HOLES ARRANGEMENT OF DRAINAGE GALLERY-L2 REFER SEPARATE DRAWINGS.



ROCK SUPPORT (CLASS-II)



ROCK SUPPORT (CLASS-III)




ROCK SUPPORT (CLASS-IV / VA)

REFERENCE DRAWINGS:-

- NHDB-4CC4-41-DD-0002

SCALE:



(SCALE = 1:50)

		एन एच पी सी लिमिटेड NHPC Limited (A GOVT. OF INDIA NAVRATNA ENTERPRISE)	
दिवांग बहुउद्देशीय परियोजना DIBANG MULTIPURPOSE PROJECT			
POWER HOUSE DRAINAGE GALLERY - L2 EXCAVATION AND ROCK SUPPORTS TYPICAL CROSS SECTIONS			
10.11.2025 DATE डिजाइन संख्या	00 NO. ड्राइंग संख्या	ISSUED FOR CONSTRUCTION REVISION OR ISSUES BY: CH. APP.	SUBMITTED RECOMMENDED APPROVED DATE NOV. 2025 DRG. NO. NHDB 4CC4 41 DD 1011 00