





PLAN




HOOK CAPACITY - 70T (QTY-3NOS.)
(NTS)




HOOK CAPACITY - 20T (QTY-2NOS.)
(NTS)




SECTION A




DETAIL 1 (NTS)



DETAIL 2 (NTS)



VIEW A (NTS)



VIEW B (NTS)

NOTES:-

1. सभी माप मिलीमीटर में तथा ऊंचाई मीटर में दिए गए हैं।
 ALL DIMENSIONS ARE IN MILLIMETERS AND LEVELS IN METERS.
2. THIS DRAWING HAS BEEN DEVELOPED BASED UPON E&M DRG. NO.-PE-DC-507-501-A001B.
3. ROCK ANCHORS, THEIR INSTALLATION, TENSIONING AND TESTING SHALL CONFORM TO SECTION B.4 OF TECHNICAL SPECIFICATION.
4. THE ROCK ANCHORS SHALL BE OF HIGH YIELD STRENGTH STEEL CONFORMING TO IS:1786. THE ANCHORAGE FOR THE FULLY GROUTED ROCK ANCHORS SHALL BE OF RESIN TYPE.
5. EACH ROCK ANCHORS SHALL BE PROVIDED WITH AT LEAST 2 NOS. NUTS AND MINIMUM FREE LENGTH OF 500MM WITH THREADING.
6. IF NECESSARY THE FREE LENGTH OF ROCK ANCHORS SHALL BE CUT OR BENT FOR PROPER PLACING OF ERECTION HOOK PLATE ASSEMBLY.
7. THE EFFECTIVENESS OF EACH 36ø ANCHORS & 32ø ANCHORS SHALL BE CHECKED FOR A LOAD OF 18T & 9T RESPECTIVELY BY CARRYING OUT PULL OUT TESTS BEFORE INSTALLING ERECTION HOOKS ASSEMBLY AND SUBJECTING IT TO THE FINAL LOADING.
8. THE CONCRETING SHALL BE DONE AS PER SECTION B.9 OF TECHNICAL SPECIFICATIONS.
9. DESIGN OF ERECTION HOOK IS IN E&M SCOPE. SUPPLY, FABRICATION & INSTALLATION OF ALL ERECTION HOOKS TO BE DONE BY CIVIL CONTRACTOR IN CLOSE COORDINATION WITH E&M CONTRACTOR.

REFERENCE DRAWINGS:-

1. NHDB-4FC4-41-DD-1002.
2. E&M DRG. NO.-PE-DC-507-501-A001B.

SCALE :

0 2.0 4.0 6.0 8.0 10.0 METRE

एन एच पी सी लिमिटेड
(भारत सरकार का उद्यम)
NHPC Limited
(A GOVT. OF INDIA ENTERPRISE)

दिबांग बहुउद्देशीय परियोजना
DIBANG MULTIPURPOSE PROJECT

MIV CAVERN
UNLOADING BAY
ERECTION HOOKS FOR EOT CRANE
ANCHORAGE DETAILS

DATE	NO.	REVISION OR ISSUES	BY	CH	APP
15.10.2025	00	ISSUED FOR CONSTRUCTION			

DESIGN MEMO NO. डिजाइन मेमो संख्या

DRAWN अंकित	SUBMITTED प्रस्तुत	RECOMMENDED अनुशंसित	APPROVED अनुमोदन
DEEPAK	PRABHAT ASWAL	RAJEEV KUMAR	DEM / HM

DATE दिनांक	DRG. NO. ड्रॉइंग संख्या					
OCT 2025	NHDB	4FC4	41	DD	1005	00

DRG. NO. NHDB-4FC4-41-DD-1005-00