




NOTES:-

1. सभी माप मिलीमीटर में तथा ऊंचाई मीटर में दिए गए हैं ।
- ALL DIMENSIONS ARE IN MILLIMETERS AND LEVELS IN METERS.
2. THE DEFINITION OF 'A', & 'B' LINE AND VARIOUS CLASSES OF EXCAVATION SHOWN SHALL BE AS PER SECTION B.3 OF TECHNICAL SPECIFICATIONS.
3. UNDERGROUND EXCAVATION INCLUDING PROTECTION OF TUNNEL INVERT SHALL BE CONFORMING TO SECTION B.3 OF TECHNICAL SPECIFICATIONS.
4. ROCK BOLTS/ANCHORS SHOWN IN THE DRAWING SHALL BE CONFORMING TO SECTION B.4 OF TECHNICAL SPECIFICATIONS.
5. MINOR MODIFICATION IN THE LENGTH, ORIENTATION, PATTERN AND LOCATION OF ROCK BOLTS/ANCHORS MAY BE DONE TO SUIT THE SITE CONDITIONS WITH THE APPROVAL OF ENGINEER-IN-CHARGE.
6. SFR SHOTCRETE SHOWN IN THE DRAWING SHALL BE APPLIED AS SPECIFIED IN SECTION B.5 OF TECHNICAL SPECIFICATIONS. IF REQUIRED, PLAIN SHOTCRETE WITH WIREMESH CAN BE USED WITH THE APPROVAL OF ENGINEER-IN-CHARGE. 50MM THK. MINIMUM SHOTCRETE SHALL BE PROVIDED AS FINAL SUPPORT IN ENTIRE LENGTH OF TUNNEL IRRESPECTIVE OF ROCK CLASS.
7. STEEL RIBS SHOWN IN THE DRAWING SHALL BE CONFORMING TO SECTION B.4 OF TECHNICAL SPECIFICATION. THE SPACING OF RIBS SHOWN MAY BE MODIFIED TO SUIT THE SITE CONDITIONS WITH THE APPROVAL OF ENGINEER-IN-CHARGE. FOR STEEL RIB DETAILS REFER DWG NO. NHDB-4CC4-41-DD-1027.
8. STEEL LAGGING OR PRE CAST CONCRETE LAGGING AS SPECIFIED IN SECTION B.4 OF TECHNICAL SPECIFICATION SHALL BE USED WITH THE APPROVAL OF ENGINEER-IN-CHARGE.
9. 45ø 5000 LONG (INTO ROCK) CONSOLIDATION GROUTING @3000 C/C STAGGERED BOTHWAYS MAY BE PROVIDED AS DIRECTED BY ENGINEER-IN-CHARGE, AS PER SECTION B.7 OF TECHNICAL SPECIFICATION.
10. PREGROUTING/FOREPOLING MAY BE USED WHERE RMR VALUE IS LESS THAN 35 OR AS DIRECTED BY ENGINEER-IN-CHARGE.
11. M25/A40 GRADE FOR INVERT & OVERT CONCRETE AND M15/A40 FOR BACKFILL CONCRETE CONFORMING TO SECTION B.9 OF TECHNICAL SPECIFICATIONS SHALL BE USED.
12. FOR CONCRETE & REINFORCEMENT DETAILS OF ACCESS GALLERY REFER SEPARATE DRAWINGS.

SCALE:



(SCALE= 1:50)

एन एच पी सी लिमिटेड (एन एच सी वी प्रभुत अस्मिन्) NHPC Limited (A GOVT. OF INDIA NAVRATNA ENTERPRISE)					
दिबांग बहुउद्देशीय परियोजना DIBANG MULTIPURPOSE PROJECT					
POWER HOUSE ACCESS GALLERY EXCAVATION AND ROCK SUPPORTS TYPICAL CROSS SECTIONS					
DR. H. V. KUMAR प्रमुख DEPARTMENT	SUBMITTED दिनांक APR. 2026	RECOMMENDED अनुमोदित DR. H. V. KUMAR	APPROVED अनुमोदित DEPARTMENT	1031	00