

ALARM ADDRESS	A18.1	ALARM NO.	2041
ALARM TEXT	DIRTY TANK TO CLEAN TANK PUMP OL.		
Related Signal	Input: X4.3 (MV154/154APC/MV204) °		
CAUSE	Breaker trip		
ACTION	1.check 3 phase voltage,and voltage phase to phase. 2.wiring loose. 3.check output relay.		