

Plant 2: $y(k) = 1.7*y(k-1) - 0.72*y(k-2) + 0.03*u(k-1)$
Ts=0.01s
BPPID与BPRBF控制器指标对比

场景	BPRBF MAE	BPPID MAE	FixPID MAE	BPRBF 超调%	BPPID 超调%	FixPID 超调%	BPRBF 稳态误差	BPPID 稳态误差	FixPID 稳态误差
8. Plant2 基本阶跃	0.0120	0.0120	0.0053	0.0%	0.0%	0.0%	0.0000	0.0000	0.0000
9. Plant2 正弦低频 (f=0.005)	0.0147	0.0170	0.0036	1.6%	1.8%	0.4%	0.0063	0.0082	0.0027
10. Plant2 正弦高频 (f=0.02)	0.0570	0.0570	0.0232	11.7%	11.7%	3.3%	0.0466	0.0466	0.0213
11. Plant2 斜坡跟踪 (0→1)	0.0002	0.0002	0.0001	0.3%	0.3%	0.3%	0.0000	0.0000	0.0000
12. Plant2 输出扰动	0.0124	0.0124	0.0058	0.2%	0.2%	0.2%	0.0000	0.0000	0.0000
13. Plant2 量测噪声	0.0219	0.0219	0.0152	4.0%	4.0%	3.7%	0.0092	0.0092	0.0088
14. Plant2 方波 (1 2)	0.0945	0.1085	0.1607	50.0%	50.0%	60.0%	0.0492	0.0464	0.1514