TENDER DOCUMENT

STO/ELEC/2026/071

Supply and installation of electrical works at Stonebridge Clinic

Employer: Stonebridge District Council

Synthetic test document - fictional data

Part C1: Tender notice and conditions

Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The building is located in Stonebridge and is used throughout the week by community groups. The area has a mild climate and rainfall is mostly in the summer months. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The existing electrical installation consists of a main board in the plant room and three sub boards.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The scope of work covers the main hall, the offices, the passages and the external areas. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The surrounding properties are residential and the nearest shop is a few hundred metres away. The external areas include a paved forecourt, a small garden and a covered walkway. The existing electrical installation consists of a main board in the plant room and three sub boards. Parking for site vehicles is available at the rear of the property near the service entrance.

The surrounding properties are residential and the nearest shop is a few hundred metres away. A previous renovation replaced the plumbing and the ceiling in the main hall. The works are located on erf 1042 and the title deed is held by the municipality.

The roof is covered with fibre cement sheeting supported on steel trusses. The existing electrical installation consists of a main board in the plant room and three sub boards. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection.

The existing electrical installation consists of a main board in the plant room and three sub boards. Electricity is supplied through a metered connection from the municipal network. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The area has a mild climate and rainfall is mostly in the summer months. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

Parking for site vehicles is available at the rear of the property near the service entrance. The municipality has operated the facility since 1996 and the local committee manages bookings. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The scope of work covers the main hall, the offices, the passages and the external areas.

Site hours of the facility are from 08:00 to 22:00 on weekdays and the caretaker locks the gates at 22:30. Electricity is supplied through a metered connection from the municipal network. The building is located in Stonebridge and is used throughout the week by community groups.

The roof is covered with fibre cement sheeting supported on steel trusses. The site is fenced and has a single vehicle gate on the northern boundary. Materials for the project are available from suppliers in the district and from the nearest regional centre.

Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The surrounding properties are residential and the nearest shop is a few hundred metres away.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The municipality has operated the facility since 1996 and the local committee manages bookings. Electricity is supplied through a metered connection from the municipal network. The existing electrical installation consists of a main board in the plant room and three sub boards. The works are located on erf 1042 and the title deed is held by the municipality.

Parking for site vehicles is available at the rear of the property near the service entrance. The surrounding properties are residential and the nearest shop is a few hundred metres away. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The municipality has operated the facility since 1996 and the local committee manages bookings. The employer's agent has prepared the specifications in accordance with standard industry practice.

The surrounding properties are residential and the nearest shop is a few hundred metres away. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The area has a mild climate and rainfall is mostly in the summer months. A previous renovation replaced the plumbing and the ceiling in the main hall. Electricity is supplied through a metered connection from the municipal network.

Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The kitchen, ablution blocks and storeroom are located on the eastern side of the building. The external areas include a paved forecourt, a small garden and a covered walkway. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. A previous renovation replaced the plumbing and the ceiling in the main hall.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The roof is covered with fibre cement sheeting supported on steel trusses. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection.

The surrounding properties are residential and the nearest shop is a few hundred metres away. Materials for the project are available from suppliers in the district and from the nearest regional centre. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The roof is covered with fibre cement sheeting supported on steel trusses.

The kitchen, ablution blocks and storeroom are located on the eastern side of the building. A previous renovation replaced the plumbing and the ceiling in the main hall. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. A previous renovation replaced the plumbing and the ceiling in the main hall. A compulsory site inspection and clarification meeting will be held at Stonebridge Clinic on Monday 9 November 2026 at 10:30, and tenderers who do not attend will be disqualified. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. Parking for site vehicles is available at the rear of the property near the service entrance.

The employer's agent has prepared the specifications in accordance with standard industry practice. Electricity is supplied through a metered connection from the municipal network. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

The area has a mild climate and rainfall is mostly in the summer months. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The roof is covered with fibre cement sheeting supported on steel trusses.

The area has a mild climate and rainfall is mostly in the summer months. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

The employer's agent has prepared the specifications in accordance with standard industry practice. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The existing electrical installation consists of a main board in the plant room and three sub boards. The works are located on erf 1042 and the title deed is held by the municipality. Parking for site vehicles is available at the rear of the property near the service entrance.

The building is located in Stonebridge and is used throughout the week by community groups. The works are located on erf 1042 and the title deed is held by the municipality. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The area has a mild climate and rainfall is mostly in the summer months. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

The employer's agent has prepared the specifications in accordance with standard industry practice. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. Electricity is supplied through a metered connection from the municipal network. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004.

Meetings of the evaluation committee are held at the civic centre and the minutes are kept by the supply chain office. The building is located in Stonebridge and is used throughout the week by community groups. A previous renovation replaced the plumbing and the ceiling in the main hall.

The existing electrical installation consists of a main board in the plant room and three sub boards. The scope of work covers the main hall, the offices, the passages and the external areas. The surrounding properties are residential and the nearest shop is a few hundred metres away.

The kitchen, ablution blocks and storeroom are located on the eastern side of the building. The scope of work covers the main hall, the offices, the passages and the external areas. Sealed tenders must be deposited in the tender box at Stonebridge Municipal Offices, 9 Demo Avenue no later than 11:00 on Friday 20 November 2026. Parking for site vehicles is available at the rear of the property near the service entrance. The building is located in Stonebridge and is used throughout the week by community groups.

The building is located in Stonebridge and is used throughout the week by community groups. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The external areas include a paved forecourt, a small garden and a covered walkway.

The scope of work covers the main hall, the offices, the passages and the external areas. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. Parking for site vehicles is available at the rear of the property near the service entrance.

Meetings of the evaluation committee are held at the civic centre and the minutes are kept by the supply chain office. The building is located in Stonebridge and is used throughout the week by community groups. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

The external areas include a paved forecourt, a small garden and a covered walkway. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. A previous renovation replaced the plumbing and the ceiling in the main hall.

Materials for the project are available from suppliers in the district and from the nearest regional centre. The external areas include a paved forecourt, a small garden and a covered walkway. The building is located in Stonebridge and is used throughout the week by community groups. The scope of work covers the main hall, the offices, the passages and the external areas.

The external areas include a paved forecourt, a small garden and a covered walkway. The area has a mild climate and rainfall is mostly in the summer months. The employer's agent has prepared the specifications in accordance with standard industry practice. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The employer's agent has prepared the specifications in accordance with standard industry practice. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The external areas include a paved forecourt, a small garden and a covered walkway. The scope of work covers the main hall, the offices, the passages and the external areas.

The scope of work covers the main hall, the offices, the passages and the external areas. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The site is fenced and has a single vehicle gate on the northern boundary.

The external areas include a paved forecourt, a small garden and a covered walkway. Electricity is supplied through a metered connection from the municipal network. The site is fenced and has a single vehicle gate on the northern boundary.

The area has a mild climate and rainfall is mostly in the summer months. Electricity is supplied through a metered connection from the municipal network. The existing electrical installation consists of a main board in the plant room and three sub boards. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The surrounding properties are residential and the nearest shop is a few hundred metres away. The works are located on erf 1042 and the title deed is held by the municipality. The municipality has operated the facility since 1996 and the local committee manages bookings. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The existing electrical installation consists of a main board in the plant room and three sub boards. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule.

The site is fenced and has a single vehicle gate on the northern boundary. The existing electrical installation consists of a main board in the plant room and three sub boards. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. Electricity is supplied through a metered connection from the municipal network. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule.

The external areas include a paved forecourt, a small garden and a covered walkway. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. Electricity is supplied through a metered connection from the municipal network. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection.

The municipality has operated the facility since 1996 and the local committee manages bookings. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. Electricity is supplied through a metered connection from the municipal network. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The building is located in Stonebridge and is used throughout the week by community groups. A previous renovation replaced the plumbing and the ceiling in the main hall. The works are located on erf 1042 and the title deed is held by the municipality. The external areas include a paved forecourt, a small garden and a covered walkway.

The roof is covered with fibre cement sheeting supported on steel trusses. The surrounding properties are residential and the nearest shop is a few hundred metres away. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The scope of work covers the main hall, the offices, the passages and the external areas. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

The facility is required to keep a register of all electrical faults reported by the caretaker. The employer's agent has prepared the specifications in accordance with standard industry practice. The surrounding properties are residential and the nearest shop is a few hundred metres away.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The works are located on erf 1042 and the title deed is held by the municipality. The municipality has operated the facility since 1996 and the local committee manages bookings. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The area has a mild climate and rainfall is mostly in the summer months.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The external areas include a paved forecourt, a small garden and a covered walkway. The building is located in Stonebridge and is used throughout the week by community groups.

The existing electrical installation consists of a main board in the plant room and three sub boards. The area has a mild climate and rainfall is mostly in the summer months. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. A previous renovation replaced the plumbing and the ceiling in the main hall. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The surrounding properties are residential and the nearest shop is a few hundred metres away. Tender rates must remain valid for 120 days after the closing date. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The works are located on erf 1042 and the title deed is held by the municipality.

Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The kitchen, ablution blocks and storeroom are located on the eastern side of the building. The external areas include a paved forecourt, a small garden and a covered walkway. A previous renovation replaced the plumbing and the ceiling in the main hall.

The roof is covered with fibre cement sheeting supported on steel trusses. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The area has a mild climate and rainfall is mostly in the summer months. The employer's agent has prepared the specifications in accordance with standard industry practice. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

Part C3: Scope of work and conditions of contract

Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The external areas include a paved forecourt, a small garden and a covered walkway. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The roof is covered with fibre cement sheeting supported on steel trusses. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. A previous renovation replaced the plumbing and the ceiling in the main hall. The works are located on erf 1042 and the title deed is held by the municipality.

The municipality has operated the facility since 1996 and the local committee manages bookings. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The scope of work covers the main hall, the offices, the passages and the external areas. The area has a mild climate and rainfall is mostly in the summer months.

Electricity is supplied through a metered connection from the municipal network. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The site is fenced and has a single vehicle gate on the northern boundary.

Materials for the project are available from suppliers in the district and from the nearest regional centre. The scope of work covers the main hall, the offices, the passages and the external areas. If preference points are claimed, a certified copy of a valid B-BBEE certificate or sworn affidavit must be submitted. The kitchen, ablution blocks and storeroom are located on the eastern side of the building. The roof is covered with fibre cement sheeting supported on steel trusses.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. Parking for site vehicles is available at the rear of the property near the service entrance. Materials for the project are available from suppliers in the district and from the nearest regional centre.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The building is located in Stonebridge and is used throughout the week by community groups. The site is fenced and has a single vehicle gate on the northern boundary.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The area has a mild climate and rainfall is mostly in the summer months. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The building is located in Stonebridge and is used throughout the week by community groups. Electricity is supplied through a metered connection from the municipal network.

Electricity is supplied through a metered connection from the municipal network. The municipality has operated the facility since 1996 and the local committee manages bookings. The external areas include a paved forecourt, a small garden and a covered walkway. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The employer's agent has prepared the specifications in accordance with standard industry practice. A previous renovation replaced the plumbing and the ceiling in the main hall. The existing electrical installation consists of a main board in the plant room and three sub boards. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The area has a mild climate and rainfall is mostly in the summer months.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The kitchen, ablution blocks and storeroom are located on the eastern side of the building. Electricity is supplied through a metered connection from the municipal network. The scope of work covers the main hall, the offices, the passages and the external areas. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

Electricity is supplied through a metered connection from the municipal network. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. Parking for site vehicles is available at the rear of the property near the service entrance. The existing electrical installation consists of a main board in the plant room and three sub boards.

Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The site is fenced and has a single vehicle gate on the northern boundary. The municipality has operated the facility since 1996 and the local committee manages bookings.

The works are located on erf 1042 and the title deed is held by the municipality. The municipality has operated the facility since 1996 and the local committee manages bookings. The community committee reports that the building is busiest on weekday evenings and on Saturdays. Electricity is supplied through a metered connection from the municipal network. The surrounding properties are residential and the nearest shop is a few hundred metres away.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The employer's agent has prepared the specifications in accordance with standard industry practice. Parking for site vehicles is available at the rear of the property near the service entrance.

Materials for the project are available from suppliers in the district and from the nearest regional centre. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The scope of work covers the main hall, the offices, the passages and the external areas. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The scope of work covers the main hall, the offices, the passages and the external areas. The community committee reports that the building is busiest on weekday evenings and on Saturdays. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The community committee reports that the building is busiest on weekday evenings and on Saturdays. The area has a mild climate and rainfall is mostly in the summer months. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection.

Electricity is supplied through a metered connection from the municipal network. Materials for the project are available from suppliers in the district and from the nearest regional centre. Parking for site vehicles is available at the rear of the property near the service entrance.

The roof is covered with fibre cement sheeting supported on steel trusses. The surrounding properties are residential and the nearest shop is a few hundred metres away. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The existing electrical installation consists of a main board in the plant room and three sub boards.

The municipality has operated the facility since 1996 and the local committee manages bookings. The external areas include a paved forecourt, a small garden and a covered walkway. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The existing electrical installation consists of a main board in the plant room and three sub boards. Parking for site vehicles is available at the rear of the property near the service entrance.

The works are located on erf 1042 and the title deed is held by the municipality. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The surrounding properties are residential and the nearest shop is a few hundred metres away. The municipality has operated the facility since 1996 and the local committee manages bookings. The site is fenced and has a single vehicle gate on the northern boundary.

Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. The building is located in Stonebridge and is used throughout the week by community groups. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The employer's agent has prepared the specifications in accordance with standard industry practice. The area has a mild climate and rainfall is mostly in the summer months. The contractor shall provide a defects liability period of 12 months from the date of practical completion. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004.

Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. A previous renovation replaced the plumbing and the ceiling in the main hall. Parking for site vehicles is available at the rear of the property near the service entrance. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

The existing electrical installation consists of a main board in the plant room and three sub boards. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. Parking for site vehicles is available at the rear of the property near the service entrance.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The existing electrical installation consists of a main board in the plant room and three sub boards. Tenderers must submit a programme showing completion within 10 weeks of the commencement date. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. The works are located on erf 1042 and the title deed is held by the municipality.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The works are located on erf 1042 and the title deed is held by the municipality. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The facility is required to keep a register of all electrical faults reported by the caretaker. The roof is covered with fibre cement sheeting supported on steel trusses. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule.

Electricity is supplied through a metered connection from the municipal network. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. A previous renovation replaced the plumbing and the ceiling in the main hall. The area has a mild climate and rainfall is mostly in the summer months.

Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule.

The employer's agent has prepared the specifications in accordance with standard industry practice. The existing electrical installation consists of a main board in the plant room and three sub boards. The roof is covered with fibre cement sheeting supported on steel trusses. The community committee reports that the building is busiest on weekday evenings and on Saturdays.

The municipality has operated the facility since 1996 and the local committee manages bookings. The community committee reports that the building is busiest on weekday evenings and on Saturdays. Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. Electricity is supplied through a metered connection from the municipal network. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

The works are located on erf 1042 and the title deed is held by the municipality. The municipality has operated the facility since 1996 and the local committee manages bookings. The existing electrical installation consists of a main board in the plant room and three sub boards. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The site is fenced and has a single vehicle gate on the northern boundary. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The building is located in Stonebridge and is used throughout the week by community groups. The site is fenced and has a single vehicle gate on the northern boundary. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The area has a mild climate and rainfall is mostly in the summer months. Materials for the project are available from suppliers in the district and from the nearest regional centre. Tenderers must provide a valid letter of good standing issued by the Compensation Fund. The site is fenced and has a single vehicle gate on the northern boundary. The employer's agent has prepared the specifications in accordance with standard industry practice.

Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life. The site is fenced and has a single vehicle gate on the northern boundary. The municipality has operated the facility since 1996 and the local committee manages bookings.

A previous renovation replaced the plumbing and the ceiling in the main hall. The works are located on erf 1042 and the title deed is held by the municipality. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

The site is fenced and has a single vehicle gate on the northern boundary. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. Parking for site vehicles is available at the rear of the property near the service entrance. The municipality has operated the facility since 1996 and the local committee manages bookings.

The employer's agent has prepared the specifications in accordance with standard industry practice. The building is located in Stonebridge and is used throughout the week by community groups. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The works are located on erf 1042 and the title deed is held by the municipality. Materials for the project are available from suppliers in the district and from the nearest regional centre.

The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. Only tenderers registered with the Construction Industry Development Board with a contractor grading of 6EP or higher in the electrical engineering works category may submit tenders. A previous renovation replaced the plumbing and the ceiling in the main hall. The employer's agent has prepared the specifications in accordance with standard industry practice.

The community committee reports that the building is busiest on weekday evenings and on Saturdays. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. The building is located in Stonebridge and is used throughout the week by community groups.

Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The building is located in Stonebridge and is used throughout the week by community groups. The kitchen, ablution blocks and storeroom are located on the eastern side of the building.

The roof is covered with fibre cement sheeting supported on steel trusses. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. Part C3 describes the extent of the works and the standard of workmanship expected in general terms.

The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices. The works are located on erf 1042 and the title deed is held by the municipality. Materials for the project are available from suppliers in the district and from the nearest regional centre.

The building is located in Stonebridge and is used throughout the week by community groups. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. Existing luminaires in the hall are fluorescent fittings that have reached the end of their service life.

Electricity is supplied through a metered connection from the municipal network. The existing electrical installation consists of a main board in the plant room and three sub boards. The scope of work covers the main hall, the offices, the passages and the external areas. The community committee reports that the building is busiest on weekday evenings and on Saturdays. The site is fenced and has a single vehicle gate on the northern boundary.

The existing electrical installation consists of a main board in the plant room and three sub boards. The building is located in Stonebridge and is used throughout the week by community groups. The surrounding properties are residential and the nearest shop is a few hundred metres away. Parking for site vehicles is available at the rear of the property near the service entrance.

Drawings of the existing layout have been prepared by the employer's agent and are available for inspection. The tender documents consist of the invitation, the conditions of tender, the scope of work and the pricing schedule. The works are located on erf 1042 and the title deed is held by the municipality.

The scope of work covers the main hall, the offices, the passages and the external areas. Part C3 describes the extent of the works and the standard of workmanship expected in general terms. Materials for the project are available from suppliers in the district and from the nearest regional centre. The area has a mild climate and rainfall is mostly in the summer months. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

Part C3 describes the extent of the works and the standard of workmanship expected in general terms. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches. Tenderers must submit a valid tax compliance status pin issued by the South African Revenue Service. The external areas include a paved forecourt, a small garden and a covered walkway. The main hall seats about two hundred people and the adjoining rooms are used as classrooms and offices.

The building is located in Stonebridge and is used throughout the week by community groups. Materials for the project are available from suppliers in the district and from the nearest regional centre. The employer's agent has prepared the specifications in accordance with standard industry practice. Stonebridge Clinic is a single-storey brick building constructed in 1987 and extended in 2004. Most of the existing wiring is concealed in the ceiling void and the roof space is accessible through two hatches.

Part C2: Pricing data - Bill of Quantities

Rates and amounts are to be completed by the tenderer.

Item	Description	Unit	Qty	Rate	Amount
SECTION: PRELIMINARIES AND GENERAL					
1.1	Health and safety plan and file	Sum	1		
1.2	Insurance and guarantees	LS	1		
SECTION: DISTRIBUTION BOARDS					
2.1	Main distribution board, 400 A, 3-phase, wall mounted, with busbars	no	1		
2.2	Sub distribution board, 63 A, 12-way, surface mounted	Nr	8		
2.3	Miniature circuit breaker, 1-pole, 32 A, 6 kA	No.	38		
SECTION: CONTAINMENT					
3.1	Galvanised cable tray, 100 mm wide, including supports	m	272.00		
3.2	PVC trunking, 100 x 50 mm (rate only)	Metre			
SECTION: CABLES					
4.1	2-core 1.5 mm2 PVC insulated copper cable, installed in conduit	Metre	121		
4.2	3-core 1.5 mm2 PVC insulated copper cable, installed in conduit	Metre	1145		
4.3	3-core 4 mm2 PVC insulated copper cable, installed in conduit	mtr	913.00		
4.4	3-core 6 mm2 PVC insulated copper cable, installed in conduit	m	324.00		
4.5	3-core 10 mm2 PVC insulated copper cable, installed in conduit	m	116.00		
4.6	3-core 16 mm2 PVC insulated copper cable, installed in conduit	mtr	531.00		
4.7	4-core 1.5 mm2 PVC insulated copper cable, installed in conduit	Metre	790		
4.8	4-core 4 mm2 PVC insulated copper cable, installed in conduit	m	430.00		
4.9	4-core 6 mm2 PVC insulated copper cable, installed in conduit	mtr	154.00		
4.10	4-core 16 mm2 PVC insulated copper cable, installed in conduit	mtr	191		
SECTION: LIGHTING					
5.1	LED panel luminaire, 600 x 600 mm, 36 W, recessed	Nr	57		
5.2	LED batten luminaire, 1200 mm, 36 W	No.	72		
SECTION: SMALL POWER					
6.1	Single switched socket outlet, 16 A	No.	52		
6.2	Data outlet, Cat 6, double	Nr	41		
SECTION: EARTHING AND TESTING					

Item	Description	Unit	Qty	Rate	Amount
7.1	Earth rod, copper clad, 1.5 m	No.	7		
7.2	Bare copper earth conductor, 16 mm2	Metre	77.00		
7.3	Testing, commissioning and certificate of compliance	sum	1		