

## Summary of Technical Changes

Section	Synopsis	References
600.24(B)	Revised title and replaced “grounded by connecting” with “connected.”	FR-7634
600.35(B)	Revised to deleted redundant text that is already required by 90.3.	SCR-19
604.100(A)	Revised title to include “tubing” to correlate with content of section.	SR-8623
604.100(A)(1)	Revised to correlate with 110.14 changes around copper-clad aluminum conductors not being dissimilar metals to copper.	FR-7713
604.100(A)(2)	Revised to add EMT to list, add acronyms, and to correlate with 110.14 changes around copper-clad aluminum conductors not being dissimilar metals to copper.	FR-7745, FR-7714, SR-8620
605.3(A) and (B)	Deleted sections.	SCR-20, CC-8193, CC-99
610.13(D)	Deleted section due to redundancy with 90.3.	SR-7777, SR-7584
620.1	Revised to relocate Informational Notes formerly under 620.2 to the scope under Informational Note No. 4 and 5.	FR-9598
620.6	Revised text into subsections for clarity.	FR-9291, SCR-5
620.12(A)(2)	Added section on Class 2 wiring and to provide minimum cable sizes.	FR-9328, SR-7510
620.12(A)(4)	Added section allowing parallel conductors in elevator traveling cables.	FR-9328
620.21	Revised to correlate with other changes in the code and to remove redundant language covered in 90.3.	SCR-6
620.21(A)(1)	Revised to list cable types for Class 2 wiring and to grant permission to use substitute cables.	FR-9327
620.21(B)(2)	Revised to list cable types for Class 2 wiring and to grant permission to use substitute cables.	FR-9309
620.21(C)(2)	Revised to list cable types for Class 2 wiring and to grant permission to use substitute cables.	FR-9304
620.22(A)	Revised to permit additional loads on car lighting branch circuit.	SR-7515
620.22(B)	Revised to add terms to align section with 620.22(A).	FR-9318
620.23 and 620.23(A)	Revised to add “truss interior lighting” for safety and enforceability.	FR-9321, SCR-7
620.25(B)	Revised to correlate with 620.22(A).	FR-9331
620.36	Revised to permit communications limited power cable, shielded pairs, coaxial cables, and communications circuits in traveling cables to accommodate communications and Class 2 applications and for compliance with 800.179.	FR-9333, SR-7545
620.37(A)	Revised text into a list format and added branch circuits identified under 620.24 to be permitted.	FR-9336, SR-7546
620.51(A)	Revised text in Exception No. 2 to identify situations where a cord-and-plug connection is permitted.	FR-9342, SR-7549
620.51(D)(1)	Deleted former subsection (D)(1) since 110.22 covers the identification requirements.	SR-7556
620.51(D)(1)	Revised for clarity and renumbered due to deletion of former subsection (D)(1).	SR-7556
620.51(E)	Revised title for consistency with Article 242 and added text requiring installation of a listed SPD.	FR-9361, SCR-8
620.62	Revised to combine two exceptions to correlate with 700.32 and 701.32.	FR-9368
625.1	Added Informational Note No. 4 and 5.	FR-9373
625.4	Revised to clarify input voltages.	FR-9403
625.6	Renumbered section for consistency and to clarify what equipment must be listed.	FR-9405, SR-7703
625.17(C)(2)	Revised to clarify output cable to primary pad measurement.	FR-9413
625.22	Revised to require a listed personnel protection system (PPS) for WPTE.	FR-9415, SR-7713