

## Summary of Technical Changes

Section	Synopsis	References
440.32	Revised to incorporate “motor” with “controller.”	FR-8083
440.62(B) and (C)	Revised to add “current” in front of “rating.”	FR-8088
445.6	Revised section to remove voltage limitations.	FR-8981
445.10	Revised text in Informational Note to align with NFPA 37.	FR-8983
445.11	Revised list items (1) and (3) and added list item (2) requiring that equipment mounted to a generator assembly cannot conceal or obscure the nameplate.	FR-8991, SR-8051
445.18	Revised section to split out generator emergency shutdown and to clarify requirements for generators in parallel.	FR-9028
445.19	Relocated from former 445.18(B) and revised for clarity.	FR-9028, SR-8052
450.2	Added section for interconnection of transformers.	SR-7862
450.3	Revised Informational Note No. 2 to include reference to IEEE standard.	FR-7787
450.3(B)	Revised to delete the exception and reformatted the notes in Table 450.3(A) and Table 450.3(B).	FR-7833
450.10	Revised section title to include “and Bonding.”	FR-7790
450.43(C)	Revised section title to “Accessibility” and added an additional requirement for personnel doors to open at least 90 degrees.	FR-7791
460.1	Revised to remove last sentence of scope.	FCR-40
460, Part II	Renumbered former Part I to new Part II and revised Part II title to “1000 Volts, Nominal, or Less.”	FR-8132, SR-7596
460, Part III	Renumbered former Part II to new Part III.	FR-8133
460.24(A)	Revised to clarify that switches must be rated for switching of capacitive loads and must open all ungrounded conductors.	FR-8111, SR-7598
460.24(B)(2)	Revised to reference section 495.22.	SR-7717
470.1	Revised to remove the last sentence of the scope.	FCR-42
470, Part II	Renumbered former Part I to new Part II and revised Part II title to “1000 Volts, Nominal, or Less.”	FCR-42
470.2	Added a section to cover reconditioned equipment.	SCR-162
470, Part III	Renumbered former Part II to new Part III.	FR-8142
480, title	Revised title of Article 480 to “Stationary Standby Batteries.”	FR-9029
480.1	Revised scope of Article 480 to stationary standby batteries having a capacity greater than 3.6 MJ (1 kWh) and added a reference to NFPA 855.	FR-9030, SR-8104
480.7	Revised to replace former terms “stationary battery system” and “battery system” with “stationary standby battery” to align with changes to the scope of the article.	FR-9059, FR-9056, FR-9060, FR-9062
480.10	Revised to replace former terms “stationary battery system” and “battery system” with “stationary standby battery” to align with changes to the scope of the article.	FR-9064, FR-9068, FR-9069, SR-8094
490	Deleted Article 490 and relocated requirements into new Article 495.	SR-7686
495	Relocated requirements from former Article 490 to create new Article 495, Equipment Over 1000 Volts ac, 1500 Volts dc, Nominal.	FR-7941
495.2	Added section to provide requirements for reconditioned equipment.	SR-7755, SCR-84
495.36	Deleted former section.	FR-7963, SR-7755
495.37	Revised section title to “Equipment Grounding Connections” and added a reference to 250.190.	FR-7964, SR-7755
495.48(A)	Revised list item (12) to align with the title of Article 242.	FR-7965