

Summary of Technical Changes

Section	Synopsis	References
337.108	Revised text to state that equipment grounding conductors be provided in multiconductor cable.	FR-8568
337.115	Revised text to allow single conductors without an overall jacket, within enclosures or machinery.	FR-8570
337.116	Revised text to allow for additional armor options.	FR-8572
338.10(B)(4)	Deleted Informational Notes.	FR-8604
338.24	Revised to specify that the major dimension (i.e., widest part) of flat cables is to be used for determining bending radius.	FR-8605
340.24	Revised text to specify that the major dimension (i.e., widest part) of flat cables is to be used for determining bending radius.	FR-8608
342.10(B)	Revised text to allow use of IMC in direct burial applications.	FR-7582
342.20(B)	Revised text to add larger sizes of IMC.	SR-8144
342.24	Revised to combine former 342.24 and 342.26 into one section and to add clarity on total degrees of bends permitted.	FR-7583
342.30(A)(3)	Added an exception that allows fishing of unbroken lengths of IMC within existing walls or panels.	FR-7584
344.10(A)(2)	Revised to remove supplementary corrosion protection requirements that are already part of 344.10(B)(2).	FR-7586
344.10(B)	Revised text to allow for use of RMC in direct burial applications.	FR-7585
344.20(A)	Revised exception text to allow for use of smaller RMC.	FR-7654
344.24	Revised to combine former 344.24 and 344.26 into one section and to add clarity on total degrees of bends permitted.	FR-7588
344.28	Revised text to require manufacturer's instructions be followed when threading conduit to prevent damage to outer coating of PVC-coated RMC and added Informational Note for reference.	FR-7589
348.2	Added section stating that FMC shall not be reconditioned.	FR-7552, SR-8141
348.24	Revised to combine former 348.24 and 348.26 into one section and to add clarity on total degrees of bends permitted.	FR-7553
348.30(A)	Revised Exception No. 4 to correlate with 350.30(A) to clarify use of listed FMC fittings as securing and supporting.	FR-7554
348.60	Revised text into list format and removed redundant requirements found in other applicable articles.	FR-7605
350.2	Added section stating that LFMC shall not be reconditioned.	FR-7556, SR-8142
350.10	Revised to remove reference to 110.14(C).	FR-7623
350.24	Revised to combine former 350.24 and 350.26 into one section and to add clarity on total degrees of bends permitted.	FR-7558
350.60	Revised text into list format and removed redundant requirements found in other applicable articles.	FR-7606
352.1	Revised to delete Informational Note.	FR-7559
352.10(B)	Added section to clearly state that PVC can be encased in concrete.	FR-7561
352.10(G)	Revised to relocate Informational Note to 352.10(K) and to correlate with new sections 352.10(K) and 352.12(C).	FR-7562
352.10(K)	Added section to clearly state that Schedule 80 PVC can be used where subject to physical damage.	FR-7563
352.12(C)	Revised to add clarity and to correlate with new sections 352.10(G) and 352.10(K).	FR-7567
352.24	Revised to combine former 352.24 and 352.26 into one section and to add clarity on total degrees of bends permitted.	FR-7569
352.44(B)	Added section to address frost heave with expansion fittings.	FR-7571