

Summary of Technical Changes

Section	Synopsis	References
520.54(K)	Revised to replace “qualified personnel” with defined term <i>qualified persons</i> .	SR-8515
520.62	Revised to incorporate listing requirements.	FR-8005
520.68(D)	Added section for special-purpose multi-circuit cable systems.	FR-8007, SCR-60
522.22	Revised Note 1 in Table 522.22 with enforceable language.	SR-8715
525.3	Deleted former 525.3(B) and (C) and relocated requirement from former 525.3(D) into 525.3(B).	FR-8017, FR-8019, FR-8021
525.31	Revised to remove non-modifying language.	FR-8023
Article 530	Revised and restructured article extensively to incorporate new technology and to apply to studios in facilities and locations staffed by qualified persons. Revised article title to replace “and Similar Locations” with “and Remote Locations.”	FR-8211, SR-8529
540.50	Deleted section.	FR-8220, FR-8221
545.22	Revised to clarify the feeder requirements for relocatable structures to be consistent with Article 550 and to add reference to 590.4(B) in Informational Note.	SR-8603
545.22(D)	Revised to divide into subsections for clarity.	FR-7705
547.1	Revised article into Part delineations and renumbered sections accordingly.	FR-7816
547.20	Revised text into list format and added Part II of Article 502 to the 547.1 allowable wiring methods.	FR-7746, FR-7816, SR-8605
547.26	Revised to not permit NM cable concealed within walls or above ceilings and added Informational Note.	FR-7748
547.27	Revised to require an insulated equipment grounding conductor if it is separate and not part of a cable assembly.	FR-7789
547.28	Revised list item (1) to replace “having” with “requiring” an equipotential plane.	SR-8619
547.41(B)(2) and (3)	Revised to remove redundant language.	FR-7750, FR-7754
547.44(B)	Revised Informational Note No. 1 and No. 2 references and clarified the bonding termination locations of the equipotential plane conductor.	FR-7771, FR-7756, SCR-124
550.10(I)	Revised to add additional raceway types and use defined terms.	FR-7763, SR-8630
550.13(B)	Revised for clarity and usability for GFCI protection.	SR-8633
550.15	Revised to clarify the intent to avoid terminating dissimilar metals.	FR-7786, SR-8640
550.16(A)(1)	Revised to add “equipment” in front of “grounding.”	FR-7792
550.16(C)(1)	Revised to add “solid, insulated, or bare” for applicability.	FR-7794
550.25	Revised to consolidate text and provide reference to Article 100.	FR-7797
550.32(A)	Revised to replace “within 30 ft” with “within sight from the mobile home it serves.”	FR-7832, SCR-92
550.33(A)	Added section for feeder equipment to address disconnecting means and renumbered former 550.33(A) to (B).	FR-7874, SR-8651
551.3	Added section around electrical datum plane distances.	FR-7873
551.30(A)	Revised to require the connection of electrical system from a generator be capable of providing an effective ground-fault return path when operational.	FR-7841
551.31(D)	Revised to replace “power supply” with “feeder” to correlate with the revised definition for <i>feeder assembly</i> .	SR-8656
551.40(A)	Revised to add the term “nominal” for consistency.	FR-7842
551.40(C)	Revised to replace “power supply” with “feeder.”	SR-8658