

Summary of Technical Changes

Section	Synopsis	References
692.41, 692.44, 692.45, 692.47	Deleted sections as they did not modify anything in Chapter 2.	FR-9311
692, Part V	Renumbered former Part VI as Part V and renumbered sections within accordingly.	FR-9312
692, Part VI	Renumbered former Part VII as Part VI and deleted former sections 692.60, 692.61, 692.62, 692.64, 692.65 as they did not modify anything in Chapters 1 through 4.	FR-9317
692.60	Added section to refer to specific Parts within Article 705.	FR-9317
692.61	Relocated former 692.59 and revised title and text around transfer switch.	FR-9317
694.1	Deleted former Informational Note Figure 694.1(b) and revised Informational Note accordingly.	FR-9485
694.7	Revised text to indicate any that construction, maintenance, associated wiring, and interconnection be performed by qualified persons	FR-9329
694.7(A)	Revised to list both onshore and offshore installations.	SR-8352
694.7(B)	Revised text to list both onshore and offshore installations and to remove redundant text.	FR-9332, SR-8352
694.7(D)	Revised title to "Overvoltage Protection" and revised text to correlate with Article 242.	FR-9334
694.15(A)	Revised to reference proper sections of the code.	FR-9335
694.24	Revised to delete the term "interactive system" for clarity.	FR-9337
694.30(A)	Revised for clarity and consistency with other articles.	FR-9489
694.54	Revised to consolidate into one referenced section.	FR-9341
694.62	Revised text align with Articles 690 and 692.	FR-9496
694.68	Deleted section as it was redundant with Article 705.	FR-9344
695.1(B)	Revised to add list item (4) and Informational Note.	FR-9007
695.2	Added section stating that reconditioned equipment is not permitted.	SR-8066
695.3(A)(3)	Revised Informational Note to correlate with NFPA 20.	FR-9072
695.3(C)(2)	Revised text to harmonize with other NFPA documents.	FR-9073
695.3(I)	Revised text to replace "shall not be permitted to be used" with "shall not be used to supply power to."	SR-8063, SR-8468
695.4(B)(1)	Revised text to correct the section reference to NFPA 20.	FR-9008
695.6(B)(1)	Revised terms and converted into list format.	FR-9012
695.6(D)	Revised text for clarity, converted to list format, and added extractions from NFPA 20.	FR-9014, SR-8064
695.6(H)	Revised text of list item (1) to include the word "ceiling."	FR-9016
695.7	Revised to correlate with NFPA 20.	FR-9017
695.7(D)	Revised to correlate with extracted material from NFPA 20.	SR-8054, SR-8469
695.10	Relocated last sentence of section regarding reconditioned equipment to new 695.2 for consistency.	SR-8065
695.15	Revised to identify SPD accurately and to add Informational Note and exception.	FR-9020, SR-8062
700.1	Revised to add Informational Note No. 1 and add a reference to NFPA 111.	FR-8773
700.2	Added section covering reconditioned equipment.	SR-7928
700.3(A)	Revised section title to "Commissioning Witness Test," revised text to add "commissioning," and added Informational Note referencing NECA 90.	FR-8784, SR-7939
700.3(F)	Revised section requirements around listing and interlocking and added new list items on connection points being located outdoors and labeled.	FR-8786