

Summary of Technical Changes

| Section | Synopsis | References |
|------------------------|---|---|
| 240.24(A) | Revised to remove vague language and to clarify exception application. | FR-7811 |
| 240.24(B)(2) | Revised to add sleeping rooms to correlate with 210.60. | FR-7812 |
| 240.24(E) | Revised to prohibit OCPDs in bathrooms and similar areas. | FR-7813 |
| 240.60(E) | Added section around listing of fuse reducers. | FR-7814 |
| 240.67 | Revised to remove delayed implementation date. | FR-7834, SR-8323 |
| 240.86(A) | Revised to include Informational Note from 240.86(B) for consistency. | FR-7927 |
| 240.86(B) | Revised Informational Note to apply to this section only. | FR-7928 |
| 240.87 | Revised to remove delayed implementation date. | FR-7818, SR-8320 |
| 240.89 | Added section requiring that replacement trip units be listed for use with the circuit breaker. | FR-7817 |
| 240, Part IX | Deleted former sections 240.100, 240.101, and 240.102 on overcurrent protection for systems rated over 1000 Vac, 1500 Vdc and relocated into new Article 245. | SR-8457 |
| 242.1 | Deleted unnecessary Informational Note. | SR-8331 |
| 242.2 | Relocated from former 240.7 to address reconditioned equipment and to correlate with other articles. | FR-7956, SR-8705 |
| 242, Part II | Deleted Informational Note as it no longer applicable. | FR-7955 |
| 242.6 | Relocated requirements from former 242.8. | FR-7962 |
| 242.8 | Relocated requirements from former 242.10. | FR-7962 |
| 242.9 | Added section to require functional indication on an SPD. | FR-7957 |
| 242.12 | Relocated requirements from former 242.6. | FR-7962 |
| 242.13 | Relocated requirements from former 242.12. | FR-7962 |
| 242.26 | Deleted section. | FR-7949 |
| 242.28 | Revised text to add "SPD line conductors and conductors to ground" for clarity and accuracy. | FR-7934, SR-8334 |
| 242.42 | Revised text to remove reference to a product no longer produced and consolidated text into one list for clarity. | FR-8283, FR-7952, SR-8335 |
| Article 245 | Created new article for overcurrent protection for systems rated over 1000 Vac, 1500 Vdc, comprised of requirements from Article 240. | FCR-387, SR-7853, SCR-87, SCR-88 |
| 250.1 | Revised to clarify list item (6). | FR-7985 |
| 250.3 | Deleted section. | FR-8247 |
| 250.6(A), (B), and (C) | Revised text to add the term "bonding" as these connections can also create objectionable currents. | FR-7990, SR-7941, SR-7938 |
| 250.20 | Revised text for clarity and correlation with other sections and added Informational Note. | FR-8159, SCR-37 |
| 250.24 | Revised text for clarity and to align with defined terms. | FR-8232, SR-7954 |
| 250.28(C) | Revised text to ensure methods for bonding jumpers are suitable. | FR-8018 |
| 250.30 | Revised text to align with defined terms and to eliminate unenforceable terms for clarity. | FR-8233, SR-7965 |
| 250.30(A)(3)(b) | Revised text for consistency with 250.24(D)(2). | FR-8233 |
| 250.36 | Revised text and title to align with defined terms for consistency and clarity. | FR-8235, SCR-38 |
| 250.52(A)(3) | Revised text and terms for consistency and clarity. | FR-8066, SR-7969 |