

Summary of Technical Changes

| Section | Synopsis | References |
|----------------|---|---------------------------------|
| 410.40 | Revised section title and removed reference to 250.112. | FR-7507, SR-8167 |
| 410.42 | Revised into list format for clarity. | FR-7617, SR-8170 |
| 410.44 | Revised section title and added reference to 410.42. | FR-7510, SCR-15 |
| 410.46 | Deleted section as content has been relocated into 410.44. | FR-7544 |
| 410.62(A) | Revised to remove “pipe size” for clarity. | FR-7512 |
| 410.62(C)(1) | Revised to include a new Informational Note referencing 400.10 and 400.12. | FR-7657 |
| 410.69 | Revised to remove effective date that had passed. | FR-7531 |
| 410.71 | Added section covering requirements for disconnecting means for fluorescent and LED luminaires that utilize double-ended lamps. | FR-7640, SR-8172 |
| 410.130(G) | Deleted section and relocated requirements to 410.71. | FR-7658 |
| 410.136(B) | Revised to reference 410.126. | FR-7682, SR-8173 |
| 410.155(B) | Revised to incorporate “equipment grounding conductor” and to reference Part V of Article 410. | FR-7524, SR-8174 |
| 410.182 | Revised to incorporate “equipment grounding conductor” and to reference Part V of Article 410 | FR-7525, SR-8175 |
| 410.184 | Revised to add an exception covering circuits exceeding 150 volts to ground and to add an Informational Note referencing UL 943C. | FR-7526 |
| 410.186 | Revised to remove “special” from fittings. | FR-7527, SR-8177 |
| 410.188 | Deleted section as it is already covered by 90.3. | FR-7529 |
| 410, Part XVII | Added Part XVII covering special provisions for germicidal irradiation luminaires. | FR-7528, SR-8178, SR-8179 |
| 411.1 | Revised the scope for clarity. | FR-7646, SCR-16 |
| 411.2 | Added section covering reconditioned equipment. | SCR-85 |
| 411.3 | Added section covering voltage limitations. | SR-8186 |
| 411.4 | Relocated former 411.3 and revised for clarity. | FR-7647, SR-8187, SR-8202 |
| 411.4(B) | Deleted section and relocated requirements to 411.2(B). | FR-7648 |
| 411.6(A) | Revised to add an exception covering secondary circuits supplied by a Class 2 power source. | FR-7652 |
| 411.7 | Revised the exception and removed redundant reference. | SR-8182 |
| 411.8 | Deleted section. | SR-8188 |
| 422.3 | Deleted section. | FR-8307 |
| 422.4 | Deleted section. | FR-8308 |
| 422.11(E) | Revised text to include “the overcurrent protection rating.” | FR-8343 |
| 422.15 | Deleted section. | FR-8352 |
| 422.16(A)(3) | Relocated requirements from former 422.43. | FR-8725 |
| 422.16(B) | Revised section to modify requirements for protecting cords from physical damage and to add “smoothed edge.” | FR-8376, SR-8315 |
| 422.18 | Revised to remove vague and unenforceable language. | FR-8364, SCR-61 |
| 422.22 | Revised to correlate with terminology in 422.18. | FR-8382 |