

Summary of Technical Changes

Section	Synopsis	References
501.10(B)(2)	Revised to delete Informational Note, to relocate concepts into list items (2) and (4), and to add Type P cable.	FR-8500
501.15(A)(4)	Relocated text from 501.10(B)(1) to this section and revised for clarity.	FR-8675, SR-7733
501.15(B)(2)	Revised to allow methods from 501.10(B)(1)(1) and 501.10(B)(6) be used and to clarify exceptions.	FR-8680
501.15(D)(1)	Revised and reorganized for clarity and to include Type P and Type TC-ER-HL cable as permissible wiring methods.	FR-8682, SR-7730
501.15(D)(2)	Revised to correct number format and clarify last sentence.	FR-8687, SCR-52
501.15(E)(1)	Revised text and exceptions for clarity and revised Exception No. 2 to align with NFPA 496.	FR-8688, SR-7735
501.30	Revised to separate grounding and bonding into two separate items, which allows for more stringent requirements to be created for bonding.	FR-8391, SR-7852
501.105(B)(6)	Revised to use defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> for clarity and to correlate with other sections and articles.	SR-7747
501.130(B)(4)	Revised exception into two positive enforceable items.	FR-8492, SR-7756
501.135(B)(4)	Added section to correct the omission of luminaires.	FR-8767
501.140(A)	Revised to correlate with definition of new defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> .	SR-7758
501.141	Added section for flexible cables, Class I, Division 2.	FR-9025, SR-7759
501.145	Revised to add listing requirement of attachment plugs and receptacles.	FR-8686
502.10	Added Informational Note referring to Article 100 for new defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> .	SR-7808
502.10(A)	Revised to change references and to correlate with definition of new defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> .	SR-7799
502.10(B)	Revised list item (2) to include supplemental corrosion protection coatings and added text to item (3) to allow for listed compression type connectors or couplings for correlation with other articles.	FR-8398, SCR-53
502.15	Revised former Informational Note into enforceable list item (5) and revised other text for conciseness.	FR-8531
502.30	Revised to separate grounding and bonding into two separate items, which allows for additional methods to be created for bonding.	FR-8383, SR-7855
502.140(A)	Revised to use the defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> for correlation.	SR-7854
502.150(A)(1)	Revised former exception into positive enforceable text.	FR-8501
502.150(A)(2)	Revised former exception into positive enforceable text.	FR-8502
502.150(B)(1)	Revised former exception into positive enforceable text.	FR-8503
502.150(B)(5)	Revised to use new defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> for correlation.	SR-7807
503.10	Revised Informational Note to refer to new defined term <i>restricted industrial establishment [as applied to hazardous (classified) locations]</i> for correlation and to correct references.	SR-7813
503.10(A)(1)	Revised to add Type P cable as acceptable.	FR-8504
503.10(A)(3)	Revised to add Type P cable as acceptable and to delete Informational Note.	FR-8480
503.10(B)	Revised former exception into positive enforceable text.	FR-8485
503.30	Revised to separate grounding and bonding into two separate items, which allows for additional methods to be created for bonding.	FR-8431, SR-7814
504.1	Revised to replace “Articles 500 through 516” with “hazardous (classified) locations.”	FR-8745