

Summary of Technical Changes

Section	Synopsis	References
701.6(C)	Revised section title to “Battery Charging Malfunction.”	FR-8877
701.10	Revised text into a list format to add requirements around loads of legally required standby systems and correlate with 700.10(B)(5)(b).	FR-8881
701.12(C)	Revised title to “Supply Duration”, relocated 701.12(D)(2) and (3) to correlate with changes in (C), and added new Informational Note to reference NFPA 110.	FR-8967, SR-8012
701.12(D)(1)	Revised to replace “service” with “power source,” which allows other types of sources for the normal power.	FR-8965
701.12(D)(2) and (3)	Relocated to 701.12(C)(2) and (3), revised for clarity, and renumbered accordingly.	FR-8967
701.12(E)	Revised title to “Stored-Energy Power Supply Systems (SEPSS),” revised text into list format to add currently available technologies that can be used with SEPSS, and added Informational Note referencing NFPA 853 and 855.	FR-8886, SR-8015
701.12(F)	Revised text to correlate with 700.12(F).	FR-8889
701.12(H)	Relocated from former 701.12(I), revised title to “Microgrid Systems,” and removed dc specific references throughout the section.	FR-8969, FR-8891
701.12(I)	Relocated from former 701.12(J), revised to correlate with other sections, and revised title to “Battery-Equipped Emergency Luminaires, Used for Legally Required Standby Systems.”	FR-8893
701.32	Revised text into subsections and modified OCPD language to bring awareness to both upstream and downstream applications.	FR-8895
702.1	Relocated Informational Note from 702.2 to 702.1.	FR-9618
702.2	Added section for “Reconditioned Equipment” and to state that it is not permitted.	SR-8024
702.4(A)	Deleted former section 702.4(A) due to redundancy with 110.9 and 110.10 and renumbered sections accordingly.	SR-8020
702.4(A)	Revised text for clarity, revised subsection titles, and added Informational Note.	FR-8898, SR-8021
702.5(A)	Revised to add references to interconnection and removed redundant reconditioning requirements now covered in 702.2.	FR-9614
702.5(B)	Revised title to “Meter-Mounted Transfer Switch” and consolidated text into single section.	SR-8112, SR-8115
702.7(A)	Revised to add requirement for signage to be placed at other than one- and two-family dwellings and corrected cross reference.	FR-8904
702.12(B)	Revised to require flanged inlets and other cord and plug connections to be installed outside of the building or structure.	FR-8907
705.1	Added Informational Note No. 2 and diagrams.	FR-9594
705.1	Revised Informational Note Figure 705.1 to align with terms used in Article 705 and added Informational Note No. 2.	FR-9594, SR-8359
705.5	Relocated from former 705.14, revised text for clarity, and revised title to “Parallel Operation.”	FR-9392, SR-8376
705.6	Restructured section for clarity, added Informational Note No. 1 referencing UL 1741, and added Informational Note No. 2 for equipment examples.	FR-9374, SR-8363
705.11	Revised section title to “Source Connections to a Service” and extensively revised subsections around conductor ampacity, disconnecting means, bonding and grounding, and overcurrent protection.	FR-9380, SR-8375
705.12	Revised and reorganized section under new subsections “Feeders and Feeder Taps” and “Busbars.”	FR-9389, SR-8364
705.13	Revised section title to “Energy Management Systems (EMS),” condensed into one section, and revised cross reference.	FR-9391, SCR-72
705.16	Deleted section due to unenforceable language and redundancy with 110.9 and 110.10.	FR-9394
705.20	Revised text for specific source disconnecting means, revised cross references, and added Informational Note to reference other applicable code sections.	FR-9395, SCR-73
705.25	Revised text to clarify that section only applies to power source output circuit conductors.	FR-9397, SR-8383