

BRANDED INSPECTION REPORT

CUSTOMER

Northwind Co.

SITE

Warehouse 3, Dock B

SERVICE DATE

2026-06-16

EQUIPMENT

Backup generator G-500

INSPECTION STATUS

Approved with recommendations

TOTAL COST

\$1,299.50

TECHNICIAN NOTES

The generator started normally, voltage was stable, and no fuel leaks were detected. The air filter is near the replacement threshold.

RECOMMENDATIONS

Replace the air filter within 30 days and schedule a load test next quarter.

CUSTOMER	Northwind Co.
SITE	Warehouse 3, Dock B
SERVICE DATE	2026-06-16
EQUIPMENT	Backup generator G-500
INSPECTION STATUS	Approved with recommendations

TECHNICIAN NOTES	The generator started normally, voltage was stable, and no fuel leaks were detected. The air filter is near the replacement threshold.
RECOMMENDATIONS	Replace the air filter within 30 days and schedule a load test next quarter.
TOTAL COST	\$1,299.50