

GOVERNMENT OF WEST BENGAL
Office of the Director General
West Bengal Fire & Emergency Services
13-D. Mirza Ghalib Street, Kolkata - 700 016

Memo No.: WBFES/1269/2023/e/12907/22-23

Date: 12.04.23

From : Director
West Bengal Fire & Emergency Services

To : The Authorised Signatory
KHARAGPUR VISION ACADEMY (C.B.S.E SCHOOL) SADATPUR,
KHARAGPUR, DIST -PASCHIM MEDINIPUR, PIN - 721301.

Sub : Corrigendum in respect of Renewal of Fire Safety Certificate (AIN :
0125191221500088) issued vide memo no. :IND/WB/FES/20192020/63993
dated: 28.02.2023.

Ref : Letter No. KVA/S/993 Dated: 01.03.2023.

Please read: Renewal of Fire Safety Certificate for an existing construction of G+IV storied under group Educational Building in the name of ' Kharagpur Vision Academy (C.B.S.E SCHOOL) at the Sadatpur, Rakhajungle, P.S.- Kharagpur, Dist-Paschim Medinipur, PIN-721301.

This is further instructed that all recommended Fire & Life Safety arrangements mentioned in the aforesaid memo number to be followed strictly.

Director

West Bengal Fire & Emergency Services

Sk ml Aziz
Secretary
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653

S. Chakrabarty
Principal
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653



Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/63993

Date: 28-02-2023

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: KHARAGPUR VISION ACADEMY (C.B.S.E SCHOOL)
SADATPUR, KHARAGPUR, DIST -PASCHIM MEDINIPUR, PIN - 721301

Sub: Renewal of Fire Safety Certificate for an existing construction of G+III storied under group Educational Building in the name of ' Kharagpur Vision Academy (B.ED & D.EL.Ed College) at the Sadalour, Rakhajungle, P.S.-Kharagpur, Dist-Paschim Medinipur, PIN-721301.

This is in reference to your application no. 0125191221500088 dated 20-10-2022 regarding the Renewal of Fire Safety Certificate for an existing construction of G+III storied under group Educational Building in the name of ' Kharagpur Vision Academy (B.ED & D.EL.Ed College) at the Sadalour, Rakhajungle, P.S.-Kharagpur, Dist-Paschim Medinipur, PIN-721301.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

Sk md Aziz
Secretary
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At Sadatpur, Kharagpur,
Paschim Medinipur-721301

S. Chakrabarty
Principal
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At Sadatpur, Kharagpur,
Paschim Medinipur-721301
CBSE Aff. No : 2430236, Code: 15653

1. STANDBY FIRE FIGHTING SYSTEM TO BE INSTALLED WITH AUTO START ARRANGEMENT
2. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way. CBSE Aff. No : 2430236, Code: 15653
3. The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191221500088.

Page : 1

- 4.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
- 5.Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 6.A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the building.
- 7.The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
- 8.The employees and security staff shall be conversant with installed fire fighting equipments of the buildings and to operate in the event of fire and testing.
- 9.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
- 10.Transformer and switch gear shall be protected with automatic CO2 or DCP Fire extinguishers confirming I.S. specifications.
- 11.A trained Fireman shall be maintained round the clock for fire safety of the building.
- 12.First Aid fire fighting system shall be provided as per I.S. specifications.
- 13.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
- 14.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 15.Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
- 16.Periodical flashing of water in the Hydrants pipe line and sprinkler shall be made to maintain the efficient working performance of above mentioned system.
- 17.The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
- 18.This Renewal of Fire Safety Certificate is valid for 03 (Three) years and has to be renewed within stipulated period from the date of issuance of this letter, from the Director General, West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Memo No.: IND/CESE/2013/2020/163523

Su md Aziz
Secretary
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653

S. Chakrabarty
Principal
Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653

Signature valid

Digitally signed by RANJAN ROY
Date: 2023.02.28 16:04:56 IST

Divisional Fire Officer
West Bengal Fire & Emergency Services

Memo No.: IND/WB/FES/20192020/63553

Sk md Aziz
Secretary

Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653

S. Chakrabarty
Principal

Kharagpur Vision Academy
(An English Medium Co-Educational Sr. Secondary School)
At-Sadatpur, Kharagpur,
Paschim Medinipur -721301
CBSE Aff. No : 2430236, Code: 15653

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0126191221500088.

Page : 3

Powered By emSigner For secure paperless solutions
Please visit www.emsigner.com