

2010 ADA Standards for Accessible Design (excerpt)

Chapter 4: Accessible Routes

403 Walking Surfaces

403.1 General.

Walking surfaces that are a part of an accessible route shall comply with 403.

403.5 Clearances.

Walking surfaces shall provide clearances complying with 403.5.

403.5.1 Clear Width.

Except as provided in 403.5.2 and 403.5.3, the clear width of walking surfaces shall be 36 inches (915 mm) minimum.

404 Doors, Doorways, and Gates

404.1 General.

Doors, doorways, and gates that are part of an accessible route shall comply with 404.

404.2 Manual Doors, Doorways, and Manual Gates.

Manual doors and doorways and manual gates intended for user passage shall comply with 404.2.

404.2.3 Clear Width.

Door openings shall provide a clear width of 32 inches (815 mm) minimum. Clear openings of doorways with swinging doors shall be measured between the face of the door and the stop, with the door open 90 degrees.

404.2.5 Thresholds.

Thresholds, if provided at doorways, shall be 1/2 inch (13 mm) high maximum.

404.2.9 Door and Gate Opening Force.

Fire doors shall have a minimum opening force allowable by the appropriate administrative authority. The force for pushing or pulling open a door or gate other than fire doors shall be 5 pounds (22.2 N) maximum for interior hinged doors and gates.

405 Ramps

405.1 General.

Ramps on accessible routes shall comply with 405.

405.2 Slope.

Ramp runs shall have a running slope not steeper than 1:12.

405.5 Clear Width.

The clear width of a ramp run and, where handrails are provided, the clear width between handrails shall be 36 inches (915 mm) minimum.

Chapter 5: General Site and Building Elements

504 Stairways

504.1 General.

Stairs shall comply with 504.

504.2 Treads and Risers.

Stair riser heights shall be 4 inches (100 mm) minimum and 7 inches (180 mm) maximum. Stair tread depths shall be 11 inches (280 mm) minimum.

Egress: Emergency Escape and Rescue Openings

1030 Emergency Escape and Rescue Openings

1030.1 General.

Sleeping rooms and habitable spaces shall be provided with emergency escape and rescue openings complying with 1030.

1030.2 Minimum Clear Width.

An emergency escape and rescue opening, including an operable window serving as the required opening, shall provide a clear opening width of 20 inches (508 mm) minimum.