

Manual Error: low values

Automated Error: Low signal: all GIC values within +/- 3.5 A;

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-05-10 00:00:00

