

Manual Error: stays at zero

Automated Error: All GIC values are positive;

All GIC values are negative;

Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (294.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-05-10 15:01:36

