

Manual Error: not smooth, values too low

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 3.5 A;

Data is constant for at least 5 minutes starting at time 2024-05-10 00:00:00

