

Manual Error: low values, not centered on zero

Automated Error: All GIC values are negative;

Low signal: all GIC values within ± 3.5 A;

Baseline offset detected (median value: -1.7 A);

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-05-10 00:21:00

