

Manual Error: not smooth

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (3600.0 seconds);

Data gap detected ≥ 10.0 minutes (3600.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-05-10 00:52:01

