

Automated Error: All GIC values are negative;

Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (3600.0 seconds);

Data gap detected ≥ 10.0 minutes (3600.0 seconds);

Data gap detected ≥ 10.0 minutes (3600 seconds) due to NaN values;

Data is constant for at least 5 minutes starting at time 2021-05-12 06:00:00

