

Automated Error: All GIC values are positive;

All GIC values are negative;

Low signal: all GIC values within  $\pm 4$  A;

Cadence is  $\geq 60$  seconds (98.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-05-02 06:00:58

