

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Excessive pre-storm noise: std before (0.1090 A) $> 1/4$ * std after (0.1528 A);

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-06-28 05:11:00

