

Automated Error: All GIC values are positive;

All GIC values are negative;

Low signal: all GIC values within ± 4 A;

Data gap detected ≥ 10.0 minutes (3180.0 seconds);

Data gap detected ≥ 10.0 minutes (3180 seconds) due to NaN values;

Data is constant for at least 5 minutes starting at time 2024-08-04 05:37:00

