

Automated Error: Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (300.0 seconds);

Data is constant for at least 5 minutes starting at time 2015-03-17 03:00:00

