

Automated Error: Low signal: all GIC values within ± 4 A;
Cadence is ≥ 60 seconds (60.0 seconds);
Data is constant for at least 5 minutes starting at time 2024-08-11 06:07:00

