

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Data gap detected ≥ 10.0 minutes (623.0 seconds);

Data gap detected ≥ 10.0 minutes (623 seconds) due to NaN values;

Data is constant for at least 5 minutes starting at time 2023-03-23 10:02:00

