

Automated Error: All GIC values are positive;
Low signal: all GIC values within ± 4 A;
Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2023-03-23 10:00:00

