

Manual Error: stays at zero

Automated Error: All GIC values are positive;

All GIC values are negative;

Low signal: all GIC values within  $\pm 4$  A;

Data gap detected  $\geq 10.0$  minutes (3240.0 seconds);

Data gap detected  $\geq 10.0$  minutes (3240 seconds) due to NaN values;

Data is constant for at least 5 minutes starting at time 2024-05-10 15:39:00

