

Automated Error: Low signal: all GIC values within ± 4 A;
Data is constant for at least 5 minutes starting at time 2025-06-01 02:01:50

