

Automated Error: All GIC values are negative;
Low signal: all GIC values within ± 4 A;
Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2025-06-01 00:04:00

