

Automated Error: All GIC values are positive;
Low signal: all GIC values within ± 4 A;
Cadence is ≥ 60 seconds (300.0 seconds);

Data is constant for at least 5 minutes starting at time 2018-08-25 18:00:00

