

Automated Error: Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (240.0 seconds);

Data is constant for at least 5 minutes starting at time 2018-08-25 18:14:00

