

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2018-08-25 18:46:00

