

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Excessive pre-storm noise: $\text{std before (0.0494 A)} > 1/4 * \text{std after (0.0485 A)}$;

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2022-04-09 05:09:00

