

Automated Error: All GIC values are positive;
All GIC values are negative;

Low signal: all GIC values within ± 4 A;

Data is constant for at least 5 minutes starting at time 2024-08-04 05:00:00

