

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Excessive pre-storm noise: $\text{std before (0.2254 A)} > 1/4 * \text{std after (0.2025 A)}$;

Cadence is ≥ 60 seconds (60.0 seconds);

Data is constant for at least 5 minutes starting at time 2024-09-16 23:30:00

