

Automated Error: All GIC values are positive;

Low signal: all GIC values within ± 4 A;

Data gap detected ≥ 10.0 minutes (3600.0 seconds);

Data gap detected ≥ 10.0 minutes (3600 seconds) due to NaN values;

Data is constant for at least 5 minutes starting at time 2017-05-27 15:15:02

