Engineering Services
4401 Green Bay Road
Kenosha WI 53144

Phone (262) 653-4315

Providing and Protecting Kenosha's Greatest Natural Resource

November 4, 2026

Kurt Davidsen, P.E.
Village Engineer
Village of Pleasant Prairie
8600 Green Bay Road
Pleasant Prairie, WI 53158

Subject: Zilber Industrial 3 at Lakeview Corporate Park

Location: West Side of Green Bay Road (STH "31") - From 108th Street to 110th Street (Approximate)

Dear Mr. Davidsen:

The Kenosha Water Utility has reviewed the plans and permit applications for the above-mentioned project. This review was performed pursuant to Paragraph 29 of the 1997 Cooperative Agreement for Orderly Development By and Between City of Kenosha and Kenosha Water Utility, and Village of Pleasant Prairie. The proposed water improvements are south of the Wholesale/Retail Dividing Line which necessitates a system level review. There are no proposed public sanitary sewer facilities associated with this project.

It is our understanding that the purpose of this project is to extend water infrastructure to service the proposed Zilber Industrial 3 development and to provide for future extension further south. The development is located on the west side of Green Bay Road (STH "31") and south of 108th Street. The proposed water main will be installed within easement outside of the public right of way.

The proposed water main will be sixteen inches in diameter. This proposed main will connect to an existing sixteen-inch main on 108th Street, on the west side of the Green Bay Road intersection. This main will continue south through easement, parallel with the Green Bay Road right of way, a total of approximately 1,100 feet.

Our review indicates that these plans are compatible with our systems and are hereby approved.

Sincerely,
Kenosha Water Utility

Ian C. Bagley, P.E.
Director of Engineering Services

CC: Curtis Czarnecki, P.E., General Manager
Sarah Tomczyk, Assistant Village Engineer
Andrew Shoaf, P.E., Pinnacle Engineering