Nitto Public Watermain: items before bidding

Zilber Industrial 3 at LakeView Corporate Park, Pleasant Prairie · Owner: TI Investors of Lakeview Nitto Parcel LLC · From Jason Lueders, 11/4/2026 · References: Project Manual 11/3/26, Public Watermain Plans 11/3/26 (rev. 4)

1. PLEASE INCORPORATE

	WHERE	CHANGE
1	Proposal form, header	Add: `LUMP SUM BID. UNIT PRICES ARE USED ONLY TO PRICE OWNER-DIRECTED CHANGES.`
2	Standard Terms s.10(a)	Change "every sixty (60) days" to "monthly" (s.10(b) already bases pay apps on month-end work).
3	Sheet C-6, SWPPP s.6	Spills reported to "THE OWNER AND THE ENGINEER" instead of "OWNER AND GENERAL CONTRACTOR". There is no GC on this contract.
4	Your CM estimate (approval letter cond. 6d)	Include survey monuments required by the DA (s.7.2) along with staking, as-builts and record drawings.

2. PLEASE CONFIRM OR ADVISE

	WHERE	QUESTION
5	Plan profiles C-3 / C-4 vs proposal form	Directional drill on the profiles is 144.7 + 196.8 = 341.5 LF; the proposal form (item 13) says 312.0 LF. Which is correct?
6	Sheet C-6 SWPPP s.5.0	Please send a fixed-fee proposal for the SWPPP inspections (7-day and 0.5" rain events), reports, rainfall log, SWPPP amendments and Notice of Termination. We will decide whether to carry it under your contract or as a fixed allowance every bidder carries.
7	Standard Terms s.7; C-1 Notes 9, 11	Permits: you are filing the WDNR extension and the WPDES NOI is the owner's. Which permits should stay with the contractor (we assume Village ROW/excavation permit and Diggers Hotline)? Please propose wording.
8	Sheet C-3; proposal form	C-3 states no work in the STH 31 right-of-way. Confirm no traffic control or WisDOT permit is needed.
9	Sheet C-1, Note 16	Water shutdowns: is this connection at the end of the line, so shutdown impact on area businesses is minimal? Who coordinates with the Village DPW?
10	Proposal form / C-3, C-4	Do you recommend potholing at known utility crossings as a bid item, or leave it in the contractor's base scope?
11	Sheet C-1, Village Note 3	Work in public easements must be by contractors prequalified under Village Ch. 405. Does the Village keep a prequalified list we should

bid from?

3. COMING FROM ZILBER

Insurance limits (s.9), indemnity (s.8 / C-1 Note 15) and delay remedies (s.5) will be matched to Zilber's standard owner-direct contract once we have it. No action needed from Pinnacle yet.

Also still open from my 11/4 email: completion date (s.5 still 7/31/2026), bid form numbering, bid instructions, CM estimate, CSM "Lakeveiw" spelling.