

UCLA CAPITAL PROGRAMS

Gafcon | Benchmark
1060 Veteran Avenue
Los Angeles, CA 90095-1365

TRANSMITTAL

No. 01005

PROJECT: CHS S Tower Seismic - Core & Shell

DATE: 2/6/2013

TO: ZGF ARCHITECTS LLP
515 South Flower Street, Suite 3700
Los Angeles, CA 90071

PROJECT NO: 945920.03

REF: Submittal 15140-004-001

ATTN: Wen Chen

WE ARE SENDING:	SUBMITTED FOR:	ACTION TAKEN:
<input checked="" type="checkbox"/> Shop Drawings	<input checked="" type="checkbox"/> Approval	<input type="checkbox"/> Approved as Submitted
<input type="checkbox"/> Letter	<input type="checkbox"/> Your Use	<input type="checkbox"/> Approved as Noted
<input type="checkbox"/> Prints	<input checked="" type="checkbox"/> As Requested	<input type="checkbox"/> Returned After Loan
<input type="checkbox"/> Change Order	<input type="checkbox"/> Review and Comment	<input type="checkbox"/> Resubmit
<input type="checkbox"/> Plans		<input type="checkbox"/> Submit
<input type="checkbox"/> Samples	SENT VIA:	<input type="checkbox"/> Returned
<input type="checkbox"/> Specifications	<input checked="" type="checkbox"/> Attached	<input type="checkbox"/> Returned for Corrections
<input checked="" type="checkbox"/> Other: Made from Submittal	<input checked="" type="checkbox"/> Separate Cover Via: E-Mail	<input type="checkbox"/> Due Date:

ITEM NO.	COPIES	DATE	ITEM	NUMBER	REV. NO.	DESCRIPTION	STATUS
	1	2/6/2013	SUB	15140-004	001	Submittal 15140-004-001 - Level 2 Core Drawings for all MEP	OPN

Remarks:

CC:

Signed: _____
Michael Thrane

**UCLA CHS South Tower Seismic Renovation
PCL PROJECT NO: 5200221**

Submittal Date: 2/6/2013

SUBMITTAL

SUBMITTAL No: 15140-004-001

Attention: Michael Thrane, Gafcon, Inc.
Address: 800 Wilshire Blvd., Suite 950, Los Angeles CA 90017
Phone: 310-206-5443
Fax:

Type of Submittal: Shop Drawings
Description: Pipe Supports -Level 2 Core Drawings for All MEP
Spec. Section: 15140-004-001
Subcontractor/Supplier: MEP

The general contractor's review of this submittal in no way relieves the subcontractor/vendor of his obligations and responsibilities for compliance with the contract documents, dimensions, quantities, design quality, nor from the responsibility for errors or omissions.

☒ Reviewed ☐ Revise & Resubmit
☐ Rejected ☐ Make Corrections Noted

Reviewed by: Andrew Fernandez Date: 2/6/2013

PCL Comments to Architect:

1. Please return two (2) copies upon review by **2/15/2013**

ARCHITECT'S & ENGINEER'S STAMP:

ZGF

ZIMMER GUNSUL FRASCA ARCHITECTS LLP

Review of submittals is only for general conformance with the design concept of the Project and general compliance with the information given in the Contract Documents. The review does not affect the Contractor's responsibility to perform all Contract requirements with no change in Contract price or time. Any actions shown by the Architect are subject to the requirements of the plans, specifications and other Contract Documents. The Contractor is responsible to confirm and correlate dimensions at the site for information that pertains to the fabrication processes, for the means, methods, techniques, procedures, sequences and quantities necessary to complete the Contract and for coordination of the work of all trades and satisfactory performance of its work. The review by the Architect is undertaken solely to satisfy the Architect's obligations, if any, to the Owner and shall not give rise to any claim by the Contractor or other parties against the Architect or Owner.


☐ No Exception Taken ☒ Make Corrections Noted ☐ Revise and Resubmit

Date 3-4-2013 By ZGF/CC/WC

<input type="checkbox"/> NO EXCEPTION TAKEN	<input type="checkbox"/> REJECTED
<input checked="" type="checkbox"/> MAKE CORRECTIONS NOTED	<input type="checkbox"/> SUBMIT SPECIFIED ITEM
<input type="checkbox"/> RESUBMITTAL NOT REQ'D	<input type="checkbox"/> REVISE AND RESUBMIT


Checking is for general conformance with the design concept of the project and general compliance with the information given in the contract documents. Any action shown is subject to the requirements of the plans and specifications. The contractor is responsible for quantities, dimensions (which shall be confirmed and correlated at the job site), fabrication processes and techniques of construction, coordination of his work with that of all other trades and satisfactory performance of his work.

IBE Consulting Engineers, Inc.
14130 Riverside Drive Suite 201, Sherman Oaks, CA 91423

 02/26/2013

PCL Construction Services, Inc.
UCLA CHS South Tower - 5200221
Submittal #: 15140-004-001
Date: 2/5/2013 **Reviewed By: Andrew Fernandez**

Reviewed for General Acceptance only. This review does not relieve the subcontractor of the responsibility for making the work conform to the requirements of the contract. The subcontractor is responsible for all dimensions, correct fabrication and accurate fit with the work of other trades.



LEVEL A 2?

SCALE: 1/8" = 1'-0"
SHEET SIZE: 30" x 54"

REV NO.	DESCRIPTION	DATE	PROJECT	UCLA CHS South Tower	DATE	02-04-13	SHEET TITLE	Composite MEP Cut & Cover Openings Level 2	DRW NO.	0-0P.2
			ADDRESS	650 Charles E Young Dr S	DESIGN BY					
			CITY	Los Angeles, CA 90024	DESIGNED BY					

Version: 2.0 Modified By: Wen Chen Modified: 4/20/2013 3:38:59 PM Status: Open

Englekirk

NOTE: 1. DO NOT CUT (E) SLAB REIN
PER PLAN NOTE 7. UNLESS APPROVED
BY SEOR.
2. OK TO CUT REIN IF NECESSARY
IN RED CLOUDS

~~LEVEL A~~ Level 2

SCALE: 1/8" = 1'-0"
SHEET SIZE: 30" x 54"