

File: 210 Hollis

BOROUGH OF NORTH FAIRHAVEN

DEPARTMENT OF BUILDINGS & CODE ENFORCEMENT
 Municipal Building, 47 Center Street, Room 12 North Fairhaven, PA 18824
 TEL (555) 217-6000 FAX (555) 217-6018

RECEIVED
AUG 15 2026
ARBOR & STONE ARCH

NOTICE OF PLAN REVIEW COMMENTS

(RETURN THIS FORM WITH RESUBMITTAL - DO NOT DETACH)

PERMIT APPL. NO.	BP-26-0917	DATE OF NOTICE	08 / 14 / 2026	REVIEW	1st [X] 2nd [] 3rd []
PROJECT	HOLLIS STREET MIXED USE - 4 STORY, 22 UNIT W/ GROUND FLOOR RETAIL			USE GROUP	R-2 / M
LOCATION	210-218 HOLLIS ST (TAX PARCEL 09-4-118, 09-4-119)			CONST TYPE	5A
APPLICANT	FAIRHAVEN HOLLIS PARTNERS LP - C/O J. MARCHETTI			ZONE	C-2 / HOD
DESIGN PROF.	ARBOR & STONE ARCHITECTURE PC - L. FEENEY, R.A. #RA-40118			SQ FT	28,440
EXAMINER	R. STANCZAK, CBO - EXT. 6014 - rstanczak@fairhaven-pa.gov				

The above referenced application has been examined for compliance with the 2018 International Building Code as adopted by the Commonwealth of Pennsylvania (34 Pa. Code Ch. 403), the Borough of North Fairhaven Zoning Ordinance, and applicable referenced standards. **THE APPLICATION IS HEREBY DISAPPROVED.** The following deficiencies shall be corrected and the corrected documents resubmitted to this office. No work shall commence until a permit is issued. Per 34 Pa. Code 403.42(c) a decision will be rendered within fifteen (15) business days of a complete resubmittal.

INSTRUCTIONS: Number your written response to correspond to the item numbers below. Place a check in the box at the left of each item when addressed. Revised sheets shall be dated and the revision clouded. Sheets not reissued shall be so noted. Incomplete responses will not be accepted at the counter.

PART I - ZONING & SITE

- ☐ 1. Front yard setback along Hollis Street is shown as 5'-0". Section 604.3 of the Zoning Ordinance requires a minimum of 10'-0" in the C-2 district unless the Historic Overlay averaging provision of Section 611.7 is applied. If averaging is claimed, provide a survey of the setbacks of the two adjoining properties on each side and a signed statement of the resulting average.
- ☐ 2. Off-street parking. 22 dwelling units at 1.5 spaces per unit = 33 required; 4,100 sf retail at 1 per 300 sf = 14 required, total 47 required. Site plan shows 31 spaces. Either revise, or apply for the parking reduction under Section 705.2 which requires a separate application to the Zoning Hearing Board. **THIS OFFICE CANNOT ISSUE A PERMIT WHILE A ZHB APPLICATION IS PENDING.**
- ☐ 3. Refuse enclosure is not shown. Provide location, dimensions, gate detail, and screening. Enclosure shall not be located within any required yard. Sec. 712.4.

PARKING SHORT 16 -- ZHB app? call J.M.

L.F. -- can we avg? see survey 8/12

- ☒ **HARB -- 9/8 mtg, appl by 8/8**
 Historic Overlay District. This property lies within the HOD. A Certificate of Appropriateness from the Historical Architectural Review Board is required prior to permit issuance for all exterior work visible from a public street. No COA is on file. Contact the HARB secretary at ext. 6031. Meetings are held the second Tuesday monthly; applications close 21 days prior.

PART II -- BUILDING / EGRESS / ACCESSIBILITY

- ☐ 5. Sheet A-2.1. The travel distance from the east end of the fourth floor corridor to the nearest exit scales at approximately 128 feet. Maximum permitted for R-2 with sprinkler system is 250 feet, however the common path of egress travel from unit 407 measures approximately ~~142 feet where 125 feet~~ is the maximum. IBC Table 1006.2.1. *Revise the layout or add an exit.*
- ☐ 6. Stair 2 discharges into the ground floor retail space. Not more than 50 percent of the exit stairways may discharge through areas on the level of exit discharge, and such discharge shall be through a protected lobby meeting IBC 1028.1 Exception 2. As drawn the discharge is through unenclosed tenant space. Revise. *over by 17 ft -- fix egress*
- ☐ 7. Accessible dwelling units. 22 units requires Type B units per IBC 1107.6.2.2.1. The unit matrix on Sheet A-0.2 identifies only 4 Type B units. Provide a complete unit-by-unit accessibility matrix. ~~Note that units served by the elevator on all floors are subject to the requirement.~~
- ☐ 8. Provide the following on the code summary sheet, which is presently incomplete: *need full matrix*
- (a) allowable area calculation per IBC 506, including frontage increase
 - (b) fire resistance rating schedule with tested assembly numbers (UL / GA)
 - (c) occupant load table by floor and by space
 - (d) plumbing fixture count per IBC Ch. 29 and the PA UCC amendments
 - (e) height and story limits with the sprinkler increase claimed
- ☐ 9. Sheet A-5.3 Detail 6. The 1 hour rated floor/ceiling assembly at the retail/residential separation is detailed with a suspended acoustical ceiling as part of the assembly. The listed assembly cited (UL 1505) does not permit this substitution. Provide a correct listed assembly and revise the detail. NOTE: this detail is referenced on A-5.1, A-5.3 and S-2.2 and must be corrected on all three.

PART III -- STRUCTURAL

- ☐ 10. Structural drawings and calculations are not sealed by a design professional registered in the Commonwealth. Sheets S-1.0 through S-4.2 bear a seal from an out of state registrant. Submit sealed documents. Act 25 of 1993.
- ☐ 11. Geotechnical report is referenced on S-1.0 (Keystone Geoscience, report dated 11/2024) but was not provided. Submit the report. The assumed bearing capacity of 3,000 psf must be substantiated.
- ☐ 12. Special inspections. Submit a statement of special inspections identifying the inspections required and the approved agency for each, signed by the registered design professional in responsible charge. IBC 1704.3. The statement submitted 07/28/2026 is not signed and does not list soils or masonry.

items 10-12: LF to reseal + send geotech 8/8

PART IV — MECHANICAL / PLUMBING / ELECTRICAL / FIRE

- ☐ 13. Sprinkler and fire alarm are indicated as deferred submittals. Deferred submittals shall be listed on the cover sheet and submitted to this office by the registered design professional in responsible charge prior to installation. Add the deferred submittal list. IBC 107.3.4.1.
- ☒ 14. Energy code compliance documentation was not submitted. Provide COMcheck for the retail portion and either COMcheck or the IECC prescriptive path for the residential portion, with envelope, mechanical, and lighting sections. Sheet is to be included in the permit set.
- ☐ 15. Sanitary lateral. Borough records indicate a single 6 inch lateral serving 210 Hollis St. The proposed building requires separate laterals for the retail and residential portions per Borough Ord. 2019-04 Sec. 8. Coordinate with the Sewer Authority and show the proposed connection on the site utility plan. A separate street opening permit is required. *call sewer auth. x6044*
- ☐ 16. ~~Water service sizing calculation was not provided.~~ Also note the existing 5/8 inch meter is not adequate. Contact North Fairhaven Municipal Authority regarding tapping fees. This item does not need to be resolved prior to permit but must be resolved prior to the rough plumbing inspection.

PART V — ADMINISTRATIVE (REQUIRED PRIOR TO ISSUANCE)

☐	Workers compensation certificate or affidavit of exemption	NOT ON FILE
☐	Contractor registration — general and each subcontractor	NOT ON FILE
☒	Application signed by owner or authorized agent	RECEIVED 07/09/26
☐	Zoning permit ZP-26-0288 — approval pending items 1-4	PENDING
☐	Sewer capacity certification	NOT ON FILE
☒	Plan review fee balance due <i>pd ok #44128/17</i>	\$ 1,847.50
☒	Erosion & sediment control approval (County Conservation District)	RECEIVED 06/22/26

Resubmit three (3) complete sets of plans, together with this notice and a written response letter. Partial sets will be rejected. Direct technical questions to the examiner at the extension above between 8:00 AM and 11:00 AM weekdays. This notice does not relieve the applicant of compliance with any code provision, whether or not cited herein, nor with any other applicable law or ordinance.


FOR THE BUILDING CODE OFFICIAL:

RJS

RAYMOND J. STANCZAK, CBO
BUILDING CODE OFFICIAL / PLANS EXAMINER
CERT. NO. PA-BCO-11482

CC: FILE / ZONING OFFICER / FIRE MARSHAL / SEWER AUTHORITY (ITEM 15) / HARB (ITEM 4)

FORM DB-14 REV. 03/2021 — BOROUGH OF NORTH FAIRHAVEN DEPT OF BUILDINGS & CODE ENFORCEMENT — APPEALS OF ANY DETERMINATION HEREIN MAY BE TAKEN TO THE BOROUGH BOARD OF APPEALS WITHIN 30 DAYS OF THE DATE OF THIS NOTICE PURSUANT TO 34 PA. CODE 403.122. RETAIN A COPY FOR YOUR RECORDS.



seal -- L.F. mailing sealed set 8/18