

MESA COUNTY ENVIRONMENTAL HEALTH

Food Facility Plan Review Program

July 28, 2026

RE: Plan Review No. EH-2026-1187

Facility: Sunrise Cafe — New Food Facility

Address: 88 Mercado Way, Suite B, Mesa County, CA

Environmental Health has completed its review of the plans submitted for the above facility. The plans cannot be approved at this time. Address the following items and resubmit corrected plans. All references are to the California Retail Food Code (CalCode) unless otherwise noted.

PLAN REVIEW COMMENTS

1. The equipment schedule does not include manufacturer specification sheets for the reach-in refrigeration units (Items 12 and 13). Submit spec sheets demonstrating NSF certification or equivalent.
2. The mop sink is shown inside the dry storage room. Relocate the mop sink so that it is not located within a food or utensil storage area, per CalCode 114281.
3. Floor sinks are not indicated for the indirect waste connections at the prep sink and the ice machine. Show floor sink locations, and confirm a minimum 1-inch air gap for all indirect drains.
4. The finish schedule lists sealed concrete for the kitchen floor but does not specify an integral coved base at the floor-wall juncture. Provide a detail showing a minimum 3/8-inch radius cove base, per CalCode 114268.
5. Hand wash sink coverage is insufficient for the back prep area. Based on the layout, staff at the rear prep table would need to pass through a doorway to reach the nearest hand sink. Add a hand wash sink serving the rear prep area.

Resubmit two corrected sets of plans along with the enclosed response form. A resubmittal fee may apply. Construction may not begin until plans are approved. Contact this office to schedule a pre-operational inspection once construction is substantially complete.

Regards,

Marcus Lee, REHS
Environmental Health Specialist II
Mesa County Environmental Health
mlee@mesacountyeh.org | (555) 022-7734