



**WARNING:**  
DO NOT SCALE THIS DRAWING. VERIFY ALL DIMENSIONS AND STRUCTURAL DETAILS ON SITE, IF IN DOUBT ASK BEFORE ACTING.

1. READ IN CONJUNCTION WITH ARCHITECTS FIT OUT DESIGN DRAWINGS.
2. READ IN CONJUNCTION WITH CORNER BASE BUILD DRAWINGS.
3. INFORMATION SUBJECT TO CONFIRMATION BY RLE ON POWER AND DATA AVAILABILITY
4. ALL ELECTRICAL SERVICES MATERIAL SELECTION AND THEIR INSTALLATION SHALL BE IN ACCORDANCE WITH ELECTRICAL SPECIFICATIONS. REFER TO SPECIFICATIONS FOR FAMILIARISATION OF ALL RELEVANT REQUIREMENTS PRIOR TO CARRYING OUT ANY INSTALLATION WORKS.
5. ALL DMC ELECTRICAL SERVICES TO BE PROVIDED BY INSTALLATION CONTRACTOR. HOLE PENETRATIONS AND EQUIPMENT MOUNTING TO BE APPROVED BY ISE STRUCTURAL ENGINEER USING CTRL APPROVED METHODS.
6. INSTALLATION CONTRACTOR TO PROVIDE ALL SPATIAL SITE CO-ORDINATION OF SERVICES AND BEST OPERATING FIT ROUTING OF SERVICES
7. ARCHITECTURAL DRAWINGS RECEIVED FROM CHAPMAN TAYLOR.
8. EXACT LOCATION OF SHELL & CORE SERVICES CONNECTIONS ONTO CORNER BASEBUILD SYSTEM SERVICES TO BE AGREED/APPROVED.
9. UNDER NO CIRCUMSTANCES MUST THE FIT-OUT CONTRACTOR INTERFERE WITH ANY ASPECT OF THE SHELL & CORE WORKS WITHOUT PRIOR APPROVAL FROM THE PROJECT MANAGER AND CORNER.
10. ALL RETAIL FIT-OUT CONTRACTORS MUST ISSUE TEST & COMPLETION/COMMISSIONING CERTIFICATION
11. ACCESS TO LANDINGS SERVICES MUST NOT BE IMPEDED BY TENANTS FIT-OUT WORKS.
12. ALL SERVICES PENETRATING FIRE BARRIERS TO BE FIRE STOPPED ACCORDINGLY. TO APPROVED PROCEDURES.
13. REFER TO DRAWING NO. 750-DLS-SPETB-00001 FOR ELECTRICAL SERVICES STANDARD SYMBOLS.
14. NEW PANELS BOARDS ADDED:
  - LV505/06 - 6 WAY 630A TP&N
  - LV505/07 - 6 WAY 800A TP&N
  - LV506/06 - 6 WAY 400A TP&N
15. BUSBARS A,B,C,D,E AMENDED TO NEW CONFIGURATIONS AS INDICATED.
16. SWITCHBOARD LV505/2
  - CABLE REF E079 (FEEDER) TO BUSBAR 'A' REMOVED
  - CABLE REF E350 TO UNIT 31 REMOVED
  - CABLE REF E352 TO UNIT 29 REMOVED
  - CABLE REF E359 TO DBE335 INSTALLED
17. SWITCHBOARD LV506/2
  - CABLE REF E072 (FEEDER) TO BUSBAR 'B' REMOVED
  - CABLE REF E360 TO DBE336 INSTALLED
18. SWITCHBOARD LV505
  - CABLE REF E011 LOAD INCREASED FROM 250A TO 400A
  - CABLE REF E365 (NEW FEEDER) TO PANEL BOARD LV505/07 ADDED
  - CABLE REF E362 (NEW FEEDER) TO PANEL BOARD LV505/06 ADDED
19. PANEL BOARD BPL/1
  - CABLE REF E355 TO DBE319 ADDED
20. SWITCHBOARD LV506
  - CABLE REF E368 (NEW FEEDER) TO PANEL BOARD LV506/06 ADDED
21. SWITCHBOARD LV505/4
  - CABLE REF E341 TO DBE333 ADDED
22. SWITCHBOARD LV506/4
  - CABLE REF E059 (FEEDER) TO BUSBAR 'C' REMOVED
  - CABLE REF E339 AND PANEL BOARD LV506/4/1 REMOVED
  - CABLE REF E340 TO DBE334 ADDED
23. PANEL BOARD LV505/06
  - CABLE REF E363 (FEEDER) TO BUSBAR 'A' ADDED
  - CABLE REF E364 (FEEDER) TO BUSBAR 'D' ADDED
24. PANEL BOARD LV506/06
  - CABLE REF E369 (FEEDER) TO BUSBAR 'D' ADDED
  - CABLE REF E370 (FEEDER) TO BUSBAR 'E' ADDED
25. SWITCHBOARD LV505/3
  - CABLE REF E339 TO RETAIL UNIT 39 REMOVED
  - CABLE REF E330 TO RETAIL UNIT 40 REMOVED
  - CABLE REF E137 TO 11.34 REMOVED
  - CABLE REF E353 TO DBE324 ADDED
26. SWITCHBOARD LV506/3
  - CABLE REF E354 TO DBE317 ADDED
27. SWITCHBOARD LV506/5
  - CABLE REF E070 LOAD INCREASED FROM 160A TO 250A
28. PANEL BOARD LV506/5/1
  - 63A TP&N SUPPLY TO DBE325 WAS 63A TP&N SUPPLY TO DBE320

L	ISSUED FOR APPROVAL - REFER TO NOTES FOR DETAILS	P.M.	02.11.07	D.W.
Mark	Revision	App'd	Drawn	Date
<div><div><b>St Pancras</b> INTERNATIONAL</div><div><b>LCR</b></div><div></div></div>				
<b>Utilities Note</b> The position of any existing public or private sewers, utility services, plant or apparatus shown on this drawing is believed to be correct, but no warranty or responsibility for its accuracy is intended. Other such plant or apparatus may also be present but not shown. The Contractor is therefore advised to undertake his own investigation where the presence of any existing sewers, services, plant or apparatus may affect his operations.				
<b>Drawing Issue Status</b>				
<b>APPROVAL</b>				

**ST PANCRAS STATION**  
**L.V. DISTRIBUTION SCHEMATIC**  
**EAST SUBSTATION**

**Client**  
**unionRAILWAYS**  
CTRL HOUSE  
2 OSSULTON STREET  
LONDON  
NW1 1HT

**pba**

**PETER BRETT ASSOCIATES**  
CAVERSHAM BRIDGE HOUSE WATERMAN PLACE READING BERKSHIRE RG1 8DN  
Tel: 0118 950 0761 Fax: 0118 959 7488 E-mail: reading@pba.co.uk Website: www.pba.co.uk © Peter Brett Associates

**Utilities Note**  
The position of any existing public or private sewers, utility services, plant or apparatus shown on this drawing is believed to be correct, but no warranty or responsibility for its accuracy is intended. Other such plant or apparatus may also be present but not shown. The Contractor is therefore advised to undertake his own investigation where the presence of any existing sewers, services, plant or apparatus may affect his operations.

Date	JUL 07	Drawn by	P.M.	Drawing Number	750-DJQ-SPETB-00263	Revision	L
AO Scale	NTS	Checked by	D.H.				