

Customer No.:		Inspect. rec. No.:		Order No.:	
---------------	--	--------------------	--	------------	--

PRO ELECTRICAL EQUIPMENT TEST REPORT

GENERAL DATA

Customer address:			Contractor:		
Description:			Electrical equipment testing report		
Type of equipment:	☐ EV cable ☐ Medical ☐ Portable appliance ☐ Machine ☐ Welding ☐ Switchgear ☐ Other ☐ CE Marketing		Reason for the test:	☐ In service ☐ Repair ☐ Periodic test ☐ Other	
Test in accordance with:	AS/NZS 3760	Start of testing:	19/07/2022	End of testing:	15/05/2024
Measuring instruments used:	Model:	MI 3340	Serial No.:	24460062	
Customer contact details:			Test engineer contact details:		

INSPECTION AND TEST RESULTS

Statement	Date of next inspection:
All electrical equipment was tested in accordance with the listed regulations and technical standards. Equipment that passed was marked appropriately and can be declared safe according to accepted technical rules. Inspection and test results are summarized in the attached pages with a recommended re-test date.	
Method of labelling	☐ Pass/Fail tags ☐ Barcoded tags ☐ RFID tags
Results:	No faults found
Notes:	

SIGNATURE AND STAMP

Client:	Operator:
☐ Report is fully accepted. Client is informed about inspection and test results. ☐ Client is informed about status of faulty equipment.	☐ Electrical equipment was tested according to valid regulations and technical standards. ☐ Faulty equipment and measures are appropriately noted.
Location: Date: Signature:	Location: Date: Signature:

PRO REPORT - TEST REGISTER

RESULTS SUMMARY						
Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
AT2005	TOASTER	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.17 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
AT2010-PH3	3 Phase RCD	CAL Room	20/07/2023		Pass	RCD: t IΔN x1, (+): 25.6 ms; t IΔN x1, (-): 35.9 ms
TTS00072	IEC Lead	CAL Room	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00199	Cal Box Lead	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00205	Instaltest Lead	CAL Room	04/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00232	IEC lead	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00233	DMM 6500	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.07 Ohm; Differential Leakage: S: 0.05 kVA; Idiff: 0.04 mA
TTS00253	IEC Lead RH	CAL Room	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00254	Cal Box	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; Differential Leakage: S: 0.02 kVA; Idiff: 0.12 mA
TTS00255	RCD Portable	CAL Room	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.04 mA; PRCD: t IΔN x1, (+): 28.1 ms; t IΔN x1, (-): 22.3 ms
TTS00305	IEC Lead	CAL Room	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0285	Extension lead	CAL Room	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00065	Microwave	Kitchen	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.06 Ohm; Differential Leakage: S: 1.27 kVA; Idiff: 0.27 mA
TTS00067	Sandwich toast	Kitchen	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.11 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00070	RCD	Kitchen	25/07/2023		Pass	RCD: t IΔN x1, (+): 8.3 ms; t IΔN x1, (-): 17.3 ms
TTS00178	Fridge	Kitchen	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.07 Ohm; Differential Leakage: S: 0.11 kVA; Idiff: 0.06 mA
TTS00186	HPM TIMER	Kitchen	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; Differential Leakage: S: 0.01 kVA; Idiff: 0.01 mA
TTS00271	Urn	Kitchen	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.16 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS0044	Fridge	Kitchen	19/01/2021		Fail	Visual: Pass; Continuity: R: >1999 Ohm; R iso EE: Nothing
TTS0091	Urn	Kitchen	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.82 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS1008	Coffee Machine	Kitchen	20/07/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.03 mA
rcd2	IEC lead	Kitchen	19/04/2024		Pass	Visual: Pass; Continuity: R: 0.14 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
RCD003	RCD	Show Room	25/07/2023		Pass	RCD: t IΔN x1, (+): 5.7 ms; t IΔN x1, (-): 15.6 ms
TTS00010	Extension lead	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS001	Scan Charger	Show Room	23/06/2021		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.14 mA
TTS00110	Lead figure 8	Show Room	04/02/2025		Pass	Visual: Pass
TTS00118	IEC lead	Show Room	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00123	IEC Lead	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00140	EFTPOS Charger	Show Room	18/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00141	IEC Lead	Show Room	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00142	Printer Charger	Show Room	18/07/2022		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.19 mA
TTS00145	IEC Lead	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00146	Printer Charger	Show Room	04/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.04 mA
TTS00149	Blue IEC Lead	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00150	Orange IEC Lead	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00167	Battery Charger	Show Room	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.05 mA
TTS00179	Iso Tx	Show Room	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.13 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00182	Iso Tx	Show Room	21/07/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.04 mA
TTS00185	Red IEC Lead	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00188	Figure 8 Lead	Show Room	23/06/2021		Pass	Visual: Pass
TTS00202	IEC Lead	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00203	Dell PC	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.11 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00204	Power board	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00219	RCD	Show Room	25/07/2023		Pass	RCD: t Δ N x1, (+): 8.4 ms; t Δ N x1, (-): 17.1 ms
TTS00220	C6 IEC Lead	Show Room	10/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00222	Scan Charger	Show Room	21/07/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.03 mA
TTS00225	Phone Charger	Show Room	20/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00226	Phone Charger	Show Room	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00227	Power Board	Show Room	21/07/2021		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Polarity: Result: Pass; Differential Leakage: S: 0.00 kVA; Idiff: 0.03 mA
TTS00228	Power Board	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Polarity: Result: Pass; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00229	Power Supply	Show Room	10/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.05 mA
TTS00230	Television	Show Room	10/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS00250	IEC Lead LH	Show Room	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00251	IEC Lead RH	Show Room	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00267	Power Board	Show Room	10/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Polarity: Result: Pass; Differential Leakage: S: 0.00 kVA; Idiff: 0.05 mA
TTS00268	Power Board	Show Room	10/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00269	Phone Charger	Show Room	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00272	Charger	Show Room	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00273	Tx	Show Room	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.03 kVA; Itou: 0.00 mA

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00274	Charger	Show Room	21/07/2023		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.01 mA
TTS003	Printer Charger	Show Room	23/06/2021		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.14 mA
TTS00307	Toaster	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.11 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00308	Iron	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS0074	Red IEC Lead	Show Room	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0088	IEC Lead	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0089	IEC Lead	Show Room	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0220	HP Printer	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; Differential Leakage: S: 0.01 kVA; Idiff: 0.14 mA
TTS2020	IEC Lead	Show Room	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS8015	RCD Portable	Show Room	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.01 mA; PRCD: t IΔN x1, (+): 15.0 ms; t IΔN x1, (-): 14.2 ms
0001	Charger	Warehouse	20/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.15 mA
0002	Charger	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.01 mA
0003	Red IEC Lead	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
00370	IEC Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
8001	Drill	Warehouse	15/05/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
AT2000	Battery Charger	Warehouse	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.05 mA
AT2002	SEW Lead	Warehouse	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
AT2004	Heat Gun	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
AT2009	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
AT2010-PH1	3 Phase RCD	Warehouse	25/07/2023		Pass	RCD: t IΔN x1, (+): 25.7 ms; t IΔN x1, (-): 35.8 ms
AT2011	RCD	Warehouse	25/07/2023		Pass	RCD: t IΔN x1, (+): 40.0 ms; t IΔN x1, (-): 29.5 ms
RCD001	RCD Cal bench	Warehouse	25/07/2023		Pass	RCD: t IΔN x1, (+): 26.3 ms; t IΔN x1, (-): 35.0 ms
RCD002	RCD 15 A	Warehouse	25/07/2023		Pass	RCD: t IΔN x1, (+): 9.3 ms; t IΔN x1, (-): 18.9 ms
TT012350	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.04 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TT012353	SEW Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.04 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00003	Scales	Warehouse	12/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00008	Electric Knife	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS00011	IEC Lead	Warehouse	17/01/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00012	Solder Station	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Differential Leakage: S: 0.10 kVA; Idiff: 0.03 mA
TTS00013	Flouro Lamp	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00014	Lamp	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.01 mA

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00015	Solder Station	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.27 Ohm; Differential Leakage: S: 0.32 kVA; Idiff: 0.26 mA
TTS00018	Power Board	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00022	IEC Lead	Warehouse	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00023	Oscilloscope	Warehouse	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; Differential Leakage: S: 0.04 kVA; Idiff: 0.20 mA
TTS00026	IEC Lead	Warehouse	20/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00027	Computer PSU	Warehouse	20/07/2022		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00028	Power Board	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Polarity: Result: Pass; Differential Leakage: S: 0.00 kVA; Idiff: 0.06 mA
TTS00033	IEC lead	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00037	DESK POWERBOARD	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00038	Desk Powerboard	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00039	Extension Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00040	Transformer	Warehouse	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.12 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00041	Drill Press	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.19 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00046	IEC Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.06 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00047	IEC lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.05 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00048	IEC Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00050	IEC lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00051	Label Printer	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.12 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Visual: Pass; Continuity: R: 0.11 Ohm; R iso EE: Um: 525 V; Riso: >200 M...
TTS00053	Label Printer	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.30 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00054	Monitor	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.28 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00059	Charger	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.00 mA
TTS00064	Vacuum Cleaner	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS00071	METREL 2121	Warehouse	23/09/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00099	C6 IEC Lead	Warehouse	21/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00100	Zebra PSU	Warehouse	21/07/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.19 mA
TTS00101	Seaward lead	Warehouse	10/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00104	Extension Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00105	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.04 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00106	IEC Lead	Warehouse	17/01/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00109	Fume Extractor	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.07 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00112	Kyoritsu Lead	Warehouse	04/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00115	Phone Charger	Warehouse	29/01/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00116	Var Tx	Warehouse	18/07/2022		Pass	Visual: Pass; Continuity: R: 0.15 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00117	Figure 8 Lead	Warehouse	22/07/2022		Pass	Visual: Pass
TTS00124	RCD Portable	Warehouse	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.03 mA; PRCD: t lΔN x1, (+): 27.7 ms; t lΔN x1, (-): 17.8 ms
TTS00125	Fig 8 Lead	Warehouse	29/01/2025		Pass	Visual: Pass
TTS00126	CT Test Box	Warehouse	22/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00127	IEC Lead	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00128	Service PC	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.08 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00129	IEC Lead	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00130	Monitor PSU	Warehouse	19/07/2022		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.07 mA
TTS00131	Laminator	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS00132	Phone Charger	Warehouse	12/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00133	IEC Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.07 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00134	Fig 8 Lead	Warehouse	12/01/2024		Pass	Visual: Pass
TTS00139	Phone Charger	Warehouse	15/02/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00143	Seaward Lead	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00147	Battery Charger	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.12 mA
TTS00148	Fig 8 Lead	Warehouse	11/01/2024		Pass	Visual: Pass
TTS00151	Power Supply	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.06 mA
TTS00152	Battery Charger	Warehouse	15/02/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.01 mA
TTS00153	Fig 8 Lead	Warehouse	15/02/2023		Pass	Visual: Pass
TTS00154	Power Supply	Warehouse	15/02/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.14 mA
TTS00155	C6 IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.12 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00156	Power Board	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00157	IEC Lead	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00158	Scales	Warehouse	19/07/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00159	C6 IEC Lead	Warehouse	13/01/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00160	Battery Charger	Warehouse	13/01/2022		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: 48.9 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.05 mA
TTS00161	Phone Charger	Warehouse	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00164	Fig 8 Lead	Warehouse	19/07/2022		Pass	Visual: Pass
TTS00165	Metrel Charger	Warehouse	19/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.14 mA

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00171	C6 IEC Lead	Warehouse	15/02/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00172	Power Supply	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.11 mA
TTS00174	Label Winder	Warehouse	12/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00183	Printer	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; Differential Leakage: S: 0.88 kVA; Idiff: 0.14 mA
TTS00190	15A IEC	Warehouse	06/01/2021		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00191	IEC Lead	Warehouse	06/01/2021		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00192	PSU	Warehouse	06/01/2021		Pass	Visual: Pass; Continuity: R: 0.08 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.18 mA
TTS00193	IEC lead	Warehouse	06/01/2021		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00194	Modem PSU	Warehouse	06/01/2021		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS00195	IEC lead	Warehouse	06/01/2021		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00197	Red IEC Lead	Warehouse	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00206	Extension Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00217	Power Supply	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.22 Ohm; Differential Leakage: S: 0.01 kVA; Idiff: 0.34 mA
TTS00218	Power Supply	Warehouse	15/02/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.14 mA
TTS00221	Kyoritsu Lead	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00223	Phone Charger	Warehouse	15/02/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00224	Kyoritsu Lead	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.06 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00235	Phone Charger	Warehouse	04/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00237	Charger	Warehouse	29/01/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.00 mA
TTS00238	Kyoritsu lead	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00239	Seaward Lead	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00241	Power Board	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.08 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00242	PC	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.11 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00243	Dyson vac	Warehouse	20/07/2022		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.06 mA
TTS00244	IEC Lead	Warehouse	15/02/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00247	Charger	Warehouse	15/02/2023		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: 73.7 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.05 mA
TTS00248	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00256	C6 IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00257	Power Supply	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.05 mA

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS00258	Power Board	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Polarity: Result: Pass; Differential Leakage: S: 0.00 kVA; Idiff: 0.07 mA
TTS00259	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.04 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00260	Power Board	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.05 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00262	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00263	Monitor	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.10 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS00264	Figure 8 Lead	Warehouse	11/01/2024		Pass	Visual: Pass
TTS00265	Printer PSU	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.01 kVA; Itou: 0.06 mA
TTS0027	Power Board	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.06 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00275	Monitor PSU	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.07 mA
TTS00276	MRL	Warehouse	29/01/2025		Pass	Visual: Pass
TTS00277	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00278	Mini PC PSU	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.06 mA
TTS00289	C6 IEC Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.08 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00290	Ultrasonic	Warehouse	12/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.14 kVA; Idiff: 0.04 mA
TTS00291	Charger	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.04 mA
TTS00294	Truecon Lead	Warehouse	12/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00296	RCD Portable	Warehouse	18/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.03 mA; PRCd: t IΔN x1, (+): 34.0 ms; t IΔN x1, (-): 17.8 ms
TTS00300	Extension lead	Warehouse	29/01/2025		Pass	Visual: Pass
TTS00306	Power Board	Warehouse	04/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00310	Power Supply	Warehouse	10/02/2025		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.06 mA
TTS00311	IEC Cable	Warehouse	17/02/2025		Pass	Visual: Pass; Continuity: R: 0.06 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS00312	Seaward Lead	Warehouse	17/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS00313	Power Supply	Warehouse	17/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.01 kVA; Idiff: 0.13 mA
TTS0059	Power Board	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.03 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0075	Extension Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS0076	Drill	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS0077	Glue Gun	Warehouse	29/01/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS0081	Fig 8 Lead	Warehouse	11/01/2024		Pass	Visual: Pass
TTS0084	Charger	Warehouse	11/01/2024		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.11 mA
TTS01001	IEC Lead	Warehouse	11/01/2024		Pass	Visual: Pass; Continuity: R: 0.05 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS01003	POWER BOARD	Warehouse	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.03 mA; Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.07 mA

Appliance ID	Type	Location	Test Date	Retest Date	Status	Test Summary
TTS01004	TSC Psu	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.13 mA
TTS1003	SEW Lead	Warehouse	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.08 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm
TTS1306	IEC Lead	Warehouse	29/01/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS168	Programme PSU	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.19 Ohm; Differential Leakage: S: 0.16 kVA; Idiff: 0.63 mA
TTS169	RCD	Warehouse	19/07/2022		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; Differential Leakage: S: 0.00 kVA; Idiff: 0.03 mA; PRCD: t Δ N x1, (+): 12.0 ms; t Δ N x1, (-): 11.5 ms
TTS170	Laminator	Warehouse	11/01/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm
TTS171	PSU	Warehouse	24/07/2023		Pass	Visual: Pass; Touch Leakage: S: 0.00 kVA; Itou: 0.04 mA
TTS2011	Instaltest Lead	Warehouse	05/02/2025		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso: >200 MOhm; Differential Leakage: S: 0.00 kVA; Idiff: 0.02 mA
TTS8003	Red IEC Lead	Warehouse	05/02/2025		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
TTS8014	Red IEC Lead	Warehouse	20/07/2023		Pass	Visual: Pass; Continuity: R: 0.09 Ohm; R iso EE: Um: 525 V; Riso: >200 MOhm; Polarity: Result: Pass
rcd3	Drill	Warehouse	15/05/2024		Pass	Visual: Pass; R iso EE: Um: 525 V; Riso-S: >200 MOhm